

ENERGY SAVING OPPORTUNITIES in CHLORE ALKALI SECTOR



**SOM DERASHRI
MD, AEA (BEE)**

INTERNATIONAL TRAINER FOR

CEA (AEE, USA), CEM (AEE, USA), CMVP(EVO, USA)



SyGuru Innovators Pvt. Ltd., Vadodara

ISO 9001:2015 CERTIFIED

info@syguruace.com, 9824079910

ENERGY SAVING OPPORTUNITIES IN CA

No	PRESENT SYSTEM	PROPOSED SYSTEM	ENERGY SAVING
1	The 48% caustic lye from CEU at 90°C is being cooled to 50°C by cooling water & then stored in the tanks for feeding to Flaker & marketing tankers	Feed 48% lye at 90°C directly to Flaker to save cooling load & again heating by steam to be fed to Flaker.	<ol style="list-style-type: none"> 1. Cooling Water 2. Energy used for reheating 48% lye from 50-60°C storage to flaker 3. Payback less than 1 year
2	The hot 48% lye from CEU is cooled by cooling water to 50-60°C & stored in tanks for marketing.	Generate hot DM water 90°C/80°C in present Ni PHE to cool the 48% lye to 81°C and use this hot water to generate chilled water in VAM 10/15°C which can be used in control room air conditioning. Further cool the 48% Lye from 81°C to 50-60°C by pre-heating the Boiler Feed Water.	<ol style="list-style-type: none"> 1. AC load from electricity to waste heat recovery VAM for control rooms 2. BFW pre heat to save NG 3. Reducing the cooling water load 4. 3. Payback less than 1 years
3	The steam from Flaker is vented to open atmosphere at 270°C from the last stage.	To utilise the vent steam after saturating it by fogger/mist and compressing it in the steam screw compressor MVR to 3.5/10 barg for utilisation as process steam.	<ol style="list-style-type: none"> 1. NG saving as MVR generates steam with COP of > 7 (for 3.5 barg) 2. Lesser Steam to be generated in boilers. 3. Water Conservation as now there is no steam vent. 4. Payback 1-2 years

ENERGY SAVING OPPORTUNITIES IN CA

N	PRESENT SYSTEM	PROPOSED SYSTEM	ENERGY SAVING
4	80 bar RLNG is reduced by PRV to 40 bar & then from 40 bar to 20 bar by PRV for use in Gas turbines.	Use NG expander to generate power by pressure reduction and also lower the cooling water temp going to Steam condenser and get better vacuum & more power.	<ol style="list-style-type: none"> 1. Additional power generation without burning NG. 2. Higher power generation in condensing steam turbine due to lower condenser temperature 3. Payback period ~ 2-3 years
5	NG boilers with flue gas exhausts at ~ 180°C is a waste of energy	Condensing Boilers to have flue gas exhausts at 55°C meeting all pollution norms as there is no Sulphur in the NG	<ol style="list-style-type: none"> 1. Saving NG 2. Saving environment – no heat exhaust 3. Payback period 1-2 years
6	<p>Electricity board Tariff has TOU</p> <p>Night: 10 pm to 6 am : Rebate of Rs 0.43/kWh</p> <p>Peak Hours: 7 to 11 am & 6 pm to 10 pm: Penalty of Rs 0.85/kWh</p> <p>ED @ 15%</p> <p>For any load shift from Peak to Night gives benefit of</p> <p>$(0.43+0.85).1.15 = \text{Rs. } 1.472/\text{kWh}$</p>	Exploit TOU and run higher CD during Night time & lower CD during Peak hrs to save Rs. 1.472/kWh without changing the daily output.	<ol style="list-style-type: none"> 1. No energy saving but Energy cost reduction by TOU exploitation of nearly 10 lakhs/yr

ENERGY SAVING OPPORTUNITIES IN CA

N	PRESENT SYSTEM	PROPOSED SYSTEM	ENERGY SAVING
7	Big Cooling water pumps (> 100 kW) are being run in parallel without knowing their efficiency.	After checking the efficiency (baseline) we guarantee 5% improvement by coating at site with just 1 day after sand blasting, pre & final special anti-corrosive, ANTI-Erosive & hydrophobic USA based coating, impeller balancing & boxup	<ol style="list-style-type: none"> 1. Improved efficiency of pump 2. Lower power consumption /higher flow per pump. 3. Enhanced pump life 4. Payback – 1-2 years
8	V belt transmission system in compressors/blowers	Sandwiched multi-layered flat belt with crowned pulleys save 5% power	<ol style="list-style-type: none"> 1. Reduced power consumption 2. Reduced slip 3. Increased belt life 4. No black particle generation 5. Payback period less than 1 yr
9	10 bar steam is fed to cell house at 1 bar thru PRV to maintain brine temperature being fed to cell.	Install Micro turbine to generate power by production	<ol style="list-style-type: none"> 1. Saves Power generated 2. Payback period less than 1 yr

DIRECT FEEDING OF 48% LYE AT 90°C FROM CEU TO CCU WITHOUT COOLING FOR STORAGE

$$\begin{aligned}48\% \text{ CSL flow to CCU} &= 10 \text{ m}^3/\text{hr} \\ &= 10 * 1.48 \\ &= 14.8 \text{ MT/Hr}\end{aligned}$$

Energy required to increase temp of 48% CSL from 60 C to 90 C in pre-heater

$$\begin{aligned}&= 14.8 * 0.826 * (90 - 60) * 1000 \\ &= 366744 \text{ kcal/hr}\end{aligned}$$

Where 0.826 is specific heat of 48 % CSL

$$\begin{aligned}\text{Running hrs. per year} &= 7920 \text{ hr/yr} \\ \text{Saving in energy per year} &= 366744 * 7920 \\ &= 2904612480 \text{ Kcal/yr}\end{aligned}$$

$$\begin{aligned}\text{Saving in steam in preheater} &= 366744 / 656 \\ &= 559 \text{ kg/hr}\end{aligned}$$

$$\text{Saving in steam per year} = 559 * 7920$$

$$= 4427763 \text{ Kg/yr}$$

$$\begin{aligned}\text{Saving in NG per year} &= 4427763 * 0.082 \text{ (0.082 is ratio of NG to steam)} \\ &= 363076 \text{ Nm}^3/\text{Hr}\end{aligned}$$

$$\text{Rate of NG} = \text{Rs.}40 / \text{Nm}^3$$

$$\begin{aligned}\text{Saving in Rs. Per Year} &= 363076 * 40 = 14523040 \text{ Rs./Yr} \\ \text{Investment in pipe line} &= \text{Rs } 10000000/- \\ \text{Payback period} &= 9 \text{ months}\end{aligned}$$

GENERATE CHILLED WATER & PREHEAT BFW FROM 48% CSL @ 90°C

***Generate hot water thru existing Ni PHE & use it in VAM to Produce Chilled Water (10/15°C)**

***Raise hot water (BFW) temperature from 55°C to 80°C.**

Calculation for a 300 TPD of 48% Lye is sold in the market

Lye volume at 48% = $300/0.48 = 625$ m³/day or 26 m³/hr

Working days in a year = 350 days / year

Power rate = Rs 8.5 / kWh, Density of 48% Lye = 1.48 kg/m³, Cp = 0.826 kcal/kg°C

Heat lost by 48% lye from 90°C to 80°C = $26 \times 1000 \times 1.48 \times 0.826 \times 10$
= 317844 kcal/hr

This is heat gained by the hot water flowing through the VAM 90/80 °C

Mass flow rate of hot water in VAM @ 95% HE eff. = $317844 \times 0.95 / (1 \times 10)$
= 30195.2 kg/hr say 30 m³/hr

Expected TR from 30 m³/hr 90/80 °C hot water VAM = 90 TR (7/12°C)

Expected cost of VAM @ Rs 33000 /TR = 30 lakhs

Cooling water needed for the VAM @ 1.27 m³/TR = 114 m³/hr for 6°C approach

Cooling Tower available (@6°C approach) = $26 \times 1000 \times 1.48 \times 0.826 \times (90-50) = 211$ m³/hr

Heat gain by 80°C Lye to pre heat Boiler feed water from 55°C (e condensate) to 80°C

Heat in 48% Lye 80°C to 55 °C for storage & HE eff 95% = $317844 \times (80-55) \times 0.95 / 10$
= 754880 kcal/hr

The BFW available at 80°C = $754880 / (1 \times 25) = 30$ TPH

Load reduction in CT $211 - 114 = 97$ m³/hr

kW saved in CT = Pump + CT Fan $(97/3600) \times 40 \times 9.81 / (0.8 \times 0.93) + 5 = 20$ kW

kW in VAM = 5 kW

Net kW saving @ 0.6 kW/TR for 90 TR = $(90 \times 0.6 + 20 - 5) \times 24 \times 350 = 579600$ kWh/yr

Net Rs power saving @ Rs 8.5/kWh = $579600 \times 8.5 =$ Rs. 49.27 lakhs/Yr

Coal Saved by BFW heating/yr = $(\text{Rs/kg } 6 / (6000 \text{ kcal/kg} \times 0.9 \text{ (eff)}) \times 754880 \times 24 \times 350 =$ Rs 70.45 lakh/yr

Total Saving in VAM + BFW Heating in Rs = 120 Lakhs/yr


Investment in VAM + PHE + pump & Piping insulations etc. = 30 + 20 + 40 = 90 Lakhs

Payback Period = 9 Months


Mechanical Vapour Recompression(MVR)

Features and Benefits:

- Certified 100% droplet-free steam
 - Peace of mind for your products and processes
- Variable speed motor
 - Efficiency
 - No energy losses with varying flow profiles
- Integrated de-superheating converting almost all compressor energy into extra steam
- Improved element design with minimal rotor backlash
 - Improved efficiency - lower running costs
- Complete installation with all connecting pipes
 - Easy on-site installation
- Low-noise operation
 - High flexibility in noise-sensitive installations
- IP23-IP55 TEFC motor
 - Excellent dust protection
- Advanced electronic control
 - Connection
 - Compatible with ES system for multiple compressors
- Superior rotor coating
 - Nickel coating for protection against corrosion
 - Walk-in capability resulting in minimal backlash



Single-stage Z VSD steam compressor



Mechanical Vapour Recompression(MVR)

Vent Steam quantity from CCU

NaOH Flake Production	250	MT/Day
NaOH Flake Production	10.4	MT/Hr
% concentration NaOH flake	98	%
Pre concentrator	48	%
Post Concentration	58	%
CP of NaOH	0.72	kcal/kg'C
Water evaporated		
water at 48% NaOH	1.083	kg/kg of NaOH
Water at 58% NaOH	0.724	kg/kg of NaOH
Water evaporated in making 48% to 58%	0.359	kg/kg of NaOH
Heat in vent steam	540	kcal/kg of steam
Heat needed to evaporate	194	kcal/kg of NaOH
Flaker		
Water at 58%	0.724	kg/kg of NaOH
Water at 98%	0.020	kg/kg of NaOH
Water quantity to be removed	0.704	kg w/kg of NaOH
Heat in vent steam	720	kcal/kg steam
Heat needed to evaporate	507	kcal/kg of NaOH
Net heat being vented	313	kcal/kg of NaOH
Steam Vented	0.434	kg/kg of NaOH
Steam temp @ venting	270	C
Steam temp after de-super heating	102	C
Steam vented super heated available for compression	4524	kg/hr
Cp of steam	0.4	kcal/kg'C
water needed to cool steam to 102'C	304033	kcal/hr
Water qty needed to de-superheat steam 270'C to 102'C	497	kg/hr
Total steam @102'C available for compression	5021	kg steam/hr

Techno-Commercial Details

Actual Conditions	Value	UOM
Max steam flow rate	5021	kg/hr
Inlet steam Pressure	0	barg
inlet steam temp	102	C
De superheating during compression	502	kg/hr
Outlet steam flow	5523	kg/hr
Outlet pressure	4.5	bara
Outlet steam Temp	158	C
Electricity input	515	kW
Enthalpy of steam	656	kcal/kg
Net enthalpy gain in compressor	554.0	kcal/kg
COP	6.91	kal/kcal
Electricity rate	8.5	Rs/kW
Steam rate	3	Rs/kg
Economics		
Saving in Steam	16570	Rs/hr
Input Power cost	4378	Rs/hr
Net Saving in Rs	12192	Rs/hr
Running Hrs	8000	Hrs/yr
Saving per year	97536794	Rs/yr
Net Saving per year by steam generation	9.75	Rs.Cr./Yr.
Expected Payback period	1.50 - 2	Years

BYE PASS PRV BY INDUCTION TURBINE 7 BAR STEAM TO 1.2 BAR


Used for Brine heating during winter 7 TPH & Summer 4 TPH.



BACK GROUND INFORMATION

Steam Parameters	Pressure	Temperature	Flow
Turbine Inlet Parameters	8.0 kg/cm ²	175°C	7.0 tph
Extraction Parameters	0.0 kg/cm ²	Nil	0.0 tph
Turbine Exhaust Parameters	1.2 kg/cm ²	123°C	7.0 tph



Steam Turbine Configuration :

Dual Entry Back Pressure ECT™ @ 12,000 r.p.m.	240 kW	IG based system
---	--------	-----------------



DESCRIPTION	VALUES	REMARKS
BASIC ASSUMPTIONS :		
Electricity (kW-h) Generated through Turbine During winter	240 kW	
Number of Hours Turbine Running per Day	24 h	
Electricity (kW-h) Generated through Turbine per Day	5,760 kWh/day	
Number of Days Turbine Running During winter	90 Op. days/yr	3 Months
Electricity units Generated through Turbine During winter	518,400 kWh	
Prevailing Electricity tariff ₹/KW-h	Rs. 7.00	Consideration
Savings over Prevailing Electricity tariff During winter	₹ 3,628,800	
Steam Flow	7,000 kg/h	
Electricity (kW-h) Generated through Turbine During other months	120kW	
Number of Hours Turbine Running per Day	24 h	
Electricity (kW-h) Generated through Turbine per Day	2,880 kWh/day	
Number of Days Turbine Running During Other months	270 Op. days/yr	9 Months
Electricity units Generated through Turbine During other months	777,600 kWh	
Prevailing Electricity tariff ₹/KW-h	Rs. 7.00	
Savings over Prevailing Electricity tariff During winter	₹ 5,443,200	
Steam Flow	4,000 kg/h	
TOTAL SAVINGS	₹ 9,072,000	
ECONOMIC CONSIDERATION		
Capital Investment		
Basic price	78,50,000	
+ CGST @ 9%	Rs. 000,000	Refundable
+ IGST @ 9%	Rs. 000,000	Refundable
Total	78,50,000	
+ Transportation	Rs. 00,000	
+ Insurance	Rs. 0,000	
+ Supervision of E & C + Service Tax (18%)	Rs. 236,000	
Landed Equipment Cost	80,86,000	
+ Indicative Cost of Balance of Plant (Customer Scope) – Civil, etc	Rs. 750,000	
Total CAPEX for the Incidental Co-Gen	Rs. 8,836,000	
PAYBACK		
Gross Savings(Annual)	Rs. 9,072,000	
Total Estimated cost	Rs. 8,836,000	
Payback	0.97 Years	
Payback in Months	11.7 mths	

LNG EXPANDER 80 BAR TO 20 BAR FOR GAS TURBINE POWER GENERATION POWER PLANT.



Some of the reputed suppliers of turbo expanders are as follows:

1. Honeywell,
2. LA TURBINE, USA,
3. Atlas Copco
4. Siemens
5. GE
6. LANGSON


LNG EXPANDER 80 BAR TO 20 BAR FOR GAS TURBINE POWER GENERATION POWER PLANT.

Presently, 2 stage expansion of LNG to 20 bar is as follows:

80/50 bar – thru a PRV under scope of LNG gas supplier (GAIL/RIL)

50/27 bar – internal to a DC

27/20 bar – PRV



Proposed: * Expander#1: 80 bar to 50 bar generating – 91 kW

* Expander#2 – 50 bar 30°C to 27 bar, 3 °C - -119 kW

* Total power Generation potential – 210 kW

* Reheat LNG after expander for process. Use cool effect in cooling water fed to a condensing steam turbine's condenser to get better vacuum & additional power

EXPLOIT TIME OF USE TARIFF HTP-1 IN GUJARAT TO SAVE ENERGY COST/MT

Power rebate during night hours - (10 pm to 6 am): Rs. 0.43/kWh

Penalty (TOU) during peak time – (7 am to 11 am) & (6 pm to 10 pm): Rs. 0.85/kwh

Normal tariff during 11 am till 6 pm – > 2500 kVA – Rs. 4.30/kWh

Elect duty@ 15%

The impact of shifting Load from peak hrs to night hrs $= (0.43 + 0.85) \times 1.15 = \text{Rs. } 1.472/\text{kWh}$

Adopt the following strategy:

to have slightly higher Current Density during night hrs: CD = 4.2

Reduce CD during the peak hours: CD = 3.8

Run Normal CD during normal hours: CD = 4

Particular	UOM	Value	Value	Value	Remarks
Rectifier efficiency	%	96	96	96	
No of Elements	Nos	100	100	100	Assumed
Area of each element	M2	2.72	2.72	2.72	Membrane area
Current I	kA	10.88	10.34	11.42	
Current Density i	kA/m2	4	3.8	4.2	
TOU Time		Normal tariff (6 am to 7 am & 11 am to 6 PM)	TOU Penalty (7 am to 11 am & 6 pm to 10 PM)	Night concession (10 pm to 6 am)	
Elect. Tariff HTP-1, Gujarat	Rs/kWh	4.3	5.15	3.87	TOU Penalty 0.85/kwh, Night rebate -0.43/kwh
Ucell	V	3.288	3.24	3.33	$U_{cell} = (U_o + k * i) v$, $U_o = 2.42v$, $k=0.217 v$
Cell Efficiency	%	97	97	97	Assumed
DC Power	kW	2673	2624	2722	$670 * \text{Cell Voltage} / \text{Cell Efficiency}$

POWER BILL WITHOUT TOU CONSIDERATION AT FIXED CD

PPC	Sr	Period	Penalty Rs/kWh	Applicable Rate Rs/kWh	TOU	Duration Hrs	CD kA/m ³	Production (32% CS Lye) TON	DC Power consumption kWh/T	Est. AC Power consumption kWh/T	Power Bill kWh/day	Power Bill Rs/day
WITHOUT TOU EXPLOITATION AS AT PRESENT	1	Peak Tariff	0.85	5.15	7 AM TO 11 AM	4	4	6.24	2673	2785	17365	89429
	2	Peak Tariff	0.85	5.15	6 PM TO 10 PM	4	4	6.24	2673	2785	17365	89429
	3	Night Tariff	-0.43	3.87	10 PM to 6 AM	8	4	12.47	2673	2785	34730	134404
	4	Normal Tariff	0	4.3	6 AM TO 7 AM	1	4	1.56	2673	2785	4341	18667
	5	Normal Tariff	0	4.3	11 AM to 6 PM	7	4	10.91	2673	2785	30389	130671
	6	Total/ Average					24	4	37.41	13367	13924	104190

POWER BILL WITH TOU EXPLOITATION

PPC	Sr	Period	Penalty Rs/kWh	Applicable Rate Rs/kWh	TOU	Duration Hrs	CD kA/m ²	Prodn. 32% CS Lye Ton/day	DC Power consumption kWh/T	Est. AC Power consumption kWh/T	Power Bill kWh/day	Power Bill Rs/day
WITH TOU EXPLOITATION	1	Peak Tariff	0.85	5.15	7 AM TO 11 AM	4	3.8	5.92	2624	2734	16193	83396
	2	Peak Tariff	0.85	5.15	6 PM TO 10 PM	4	3.8	5.92	2624	2734	16193	83396
	3	Night Tariff	-0.43	3.87	10 PM to 6 AM	8	4.2	13.09	2722	2836	37134	143709
	4	Normal Tariff	0	4.3	6 AM TO 7 AM	1	4	1.56	2673	2785	4341	18667
	5	Normal Tariff	0	4.3	11 AM to 6 PM	7	4	10.91	2673	2785	30389	130671
	6	Total/ Average					24	4	37.41	13318	13873	104251


Savings/Year > Rs. 10 lakhs , with Zero investment only by adjusting CD according to TOU TOU

COMPONENTS OF PUMP WHICH CAN IMPACT PERFORMANCE AND EFFICIENCY


AGEING & OTHER EFFECTS ON PUMP PERFORMANCE & COATING TO IMPROVE EFFICIENCY



CAVITATION



PUMP EFFICIENCY AND CRITICAL IMPACT POINTS



UPGRADING AND PROTECTING PUMP WETTING PARTS

BY

SPECIAL COATING

GUARANTEED EFFICIENCY IMPROVEMENT



PUMP COATING OBJECTIVE

- Increase Capacity (Q, H)
- Decrease Life Cycle Costs
- Increase MTBF
- Increase Pump Efficiency
- Decrease Power Consumption

(Normally after coating, the flow increases. So adjust it to the baseline to compare power saving)

- Reduced Vibration & Noise
- Decrease Maintenance

PROCEDURE FOR PUMP COATING

- **Establish base line:** Measure Flow, Head, Density before coating & calculate Pump Efficiency $\eta_p \% = \frac{\{Q(m/s).H(m).\rho(kg/m^3).g(m/sec^2)\}}{(1000.kW_{in}.\eta_m)} \cdot 100$
- Q- Ultrasonic flow meter (TTD/Doppler)
- H – Total Head (Pump Discharge Head – Suction Head)
- kW_{in} = Power input to motor (1.732 x V x I x Pf or kW)
- **Dismantle Pump*** – Sand-blast wetted parts (5 bar comp air at site) – Coating (Primary & Final) – Dry Coat – Balance Impeller – Reassemble Pump* – Measure (Q, H, kW)
- **Establish Final Efficiency %**
(A min. 5% Improvement in Efficiency is Guaranteed for old pumps > 3 years)

*Dismantling & Reassembly is in client's scope


Two pumps coating in a day is possible & one day for drying & balancing

Cooling Tower No.1 (HCl) Pump No. D performance


Particulars	Before Coating	After Coating(07.07.2022)	28.12.2022
Flow (m3/Hr)	1212	1650	1672
Suction Pr. (Mtr)	1	1	1.1
Disc. Pr. (Kg/Cm2)	3.75	3.75	3.95
Power (KW)	213.8	213.8	213.23
Motor Efficiency(%)	95	95	95
Pump Efficiency(%)	59	81	86


Cooling Tower No.1 (HCl) Pump No. B performance (Baseline data)

Particulars	Before Coating (28.12.2022)
Flow (m3/Hr)	1216
Suction Pr. (Mtr)	1
Disc. Pr. (Kg/Cm2)	3.95
Power (KW)	223.
Motor Efficiency(%)	95
Pump Efficiency(%)	60.19


P N PATEL
Sr. M (P)


H K BAJAPATI
Mgr. (E)


28/12/22
V K PATEL
Mgr. (M)


SOM DERASHRI
SIPL

IMPROVED TRANSMISSION SYSTEM

SANDWITCHED MULTILAYERED FLAT BELT FOR GUARANTEED 5% ENERGY SAVING



Guaranteed **Power Saver**
&
Longer Life than 'V' Belts

Advantages :

- Principals having over two decades of experience in belting.
- Imported high strength oriented polyamide core.
- Expertise in conversion packages for individual application of OEMs.
- Flat belts and pulley for wide range of applications.
- Safe and secured transmission.
- High accuracy in rotational speed.
- Excellent driving properties.





SANDWICH MULTILAYERED FLAT BELT WITH
CROWNED PULLEYS DRIVE SYSTEM




V BELT DRIVE SYSTEM WITH V
GROOVED PULLEYS &
MULTIPLE BELTS

V Belt vs SyGuru Sandwich Flat Belt & Crowned pulleys



Sr No.	Parameters	V Belt	SyGuru Flat Belt
1	Friction Loss	Wedging-in - Wedging-out in V groove @ 4 times RPM (1500x 4 = 6000 /minute)	Grips Crowned Pulley
2	Bending Loss	6000 times around the pulleys with thick cross section & number of belts	Thinner Cross-Section has significantly less Bending loss
3	Braking Action	Each belt has different Liner Speed ($\pi \cdot D \cdot N$) as the V groove have different depths (No QC check) thus, a narrower V groove has higher belt 'D' making that belt run faster & other with low linear speed (Dangling) V belt which also imparts a braking action resulting in Higher kW.	No differential speed as only one belt runs
4	Uneven Tension	Highest D belt takes maximum load & wears out faster & higher Slip.	Constant speed due to special MOC & lesser Slip
5	Short Life	With multiple belts only fastest running belt takes total load & results early breakdown	Guaranteed higher life compared to V belt
6	Higher Maintenance Cost	Multiple replacement & whole set is to be replaced not just the broken belt	Longer Life & Maintenance free
7	Black particle generation	Friction & wedging action results in Black particle generation in environment - unacceptable in pharma & food industry	No Black/Foreign Particle Generation eliminating chances of contamination
8	ENERGY SAVING	Higher Energy Consumption	Energy Efficient 5%+/- 2%

SYGURU FLAT BELTS EFFICIENCY COMPARED TO V BELTS



- FLAT BELT η %:
 - HIGHER AT ALL LOADS
 - UNIFORM OVER LARGE RANGE
 - 3% TO 5% HIGHER AT FULL LOADS

Sr.No.	Company Name	Equipment Name	Energy Consumed kW		% Saving
			V-Belt Drive	SyGuru Flat Belt Drive	
1	Spic Pharmaceuticals	Kirloskar Ammonia comp.	114.5	106.1	7.2
2	IPCL, BARODA	IR Compressor 75 Kw	62.5	60.3	5.5
3	Titan Industries, Hosur	K.G. Khosla Comp.	29.0	27.3	5.7
4	Indian Oil Corpn. Belgaum	IR Air Compressor	32.0	29.0	9.4
5	Spic Pharma, Coddalore	IR Compressor 75 Kw	65	61	6.2
6	India Cement Ltd., Dalvoi	Rotary Blower 30 Kw	21.3	19.8	7
7	United Beveries, Kerala	Kirloskar Ammonia comp. 75 Kw	57	52	8.7
8	Titan Industries (Jewellery)	Kirloskar Compressor	33.41	31.3	6
9	Hindustan Coca cola Beverages, B'lore	irloskar Amonia comp	75.7	68.5	9.5
10	Reliance (RIL, Naroda)	Gas Compressor	70	65	8
11	TVS Suzuki Ltd.	K.G.Khosla Comp	81	74.4	8
12	Wokhardt Limited, Ankleshwar	Roots Blower 50 HP	33	31	6
13	DCM Shriram Alkali & Chemicals, Jhagadia	Ref. Compressor	160	152	5
14	NCPL, BHARUCH	Roos Blower	37	34.0	8
15	ATUL Limited, Ankleshwar	Air Compressor	50	47	6
16	Grasim Industries, Nagda	Ref. Compressor 100 HP	63.8	61.2	4
17	Aventis Cropscience India Ltd. Ank.	Reactor, 7.5 HP	4.8	4.6	4
18	Cadila Pharmaceuticals,Ank	Ref. Compressor 75 Kw	63.8	60.6	5
19	IPCA Laboratories Ltd. Ratlam	Multi Mill, 3 HP	1.9	1.8	6
20	Gujarat Guardian Ltd, Ankleshwar	Belt Supplied for Air comp.	75	71	5
21	Jubilient Organosis, Savli	Ref. Compressor	65	60	7.6
22	RIL, Baroda	Ref. Compressor	30	28	7
23	Surya Roshni, Gwalior	Flex Blower	98	92	6.5

SOM DERASHRI

SyGuru Innovators Pvt. Ltd., BARODA

info@syguruace.com, [9824079910](tel:9824079910)

ENERGY CONSERVATION

OUR GIFT TO NEXT GENERATION

A STEP TOWARDS NET ZERO

