

**21st NATIONAL CERTIFICATION EXAMINATION
FOR
ENERGY MANAGERS & AUDITOR**

PAPER – 4: ENERGY PERFORMANCE ASSESMENT FOR EQUIPMENT AND UTILITY SYSTEM

Section - I: BRIEF QUESTIONS

Marks: 10 x 1 = 10

- i. Answer all **Ten** questions
- ii. Each question carries **ONE** mark

1	Oxygen and nitrogen present in the fuel do not contribute to calorific value of the fuel.	True/False	TRUE
2	The difference between GCV and NCV of hydrogen fuel is Zero	True/False	FALSE
3	In a refrigeration plant the higher the kW/TR, the higher will be the COP.	True/False	FALSE
4	In an integrated steel plant, pig iron is produced from Blast furnace	True/False	TRUE
5	The copper loss in the transformer is the power consumed to sustain the magnetic field in the transformer core	True/False	FALSE
6	The head generated by the centrifugal pump is proportional to the square of the density of the liquid being pumped	True/False	FALSE
7	Current THD is the ratio of the root-mean-square value of the harmonic currents to the square of the fundamental current.	True/False	TRUE
8	Both Rotary hearth and walking beam-type furnaces are continuous furnaces	True/False	TRUE
9	% Oxygen or CO ₂ in flue gas is not required to calculate the boiler efficiency by Direct method	True/False	TRUE
10	In the reheat cycle of a thermal power plant, partially expanded steam extracted from the turbine at various points are used to heat the condensate and feed water through HP/LP heaters on its way back to the boiler or steam generator.	True/False	FALSE

.....**End of Section I**.....

Section - II: SHORT NUMERICAL QUESTIONS

Marks: 2 x 5 = 10

- i. Answer all **Two** questions
- ii. Each question carries **FIVE** marks

L1	An office complex with a total built-up area of 18000 m ² is located in a warm and humid region which includes the car parking, road and basement area of around 7000 sq.m. The reported annual energy consumption is 9,73,569 units (kWh) from utility company and 25,167 units (kWh) from DG set. Calculate the EPI and AAHEPI if the facility operates for 2500 hours per year.
-----------	---

L1 S	Solution:																											
	<table border="1" style="width: 100%;"> <tr> <td>Annual Electricity Consumption, purchased from utilities</td> <td>973569</td> <td>kWh</td> </tr> <tr> <td>Annual Electricity Consumption, through Diesel Generating sets</td> <td>25167</td> <td>kWh</td> </tr> <tr> <td>Total built up area of the building</td> <td>18000</td> <td>sqm</td> </tr> <tr> <td>Parking and Basement Area</td> <td>7000</td> <td>sqm</td> </tr> <tr> <td>Annual Working hours</td> <td>2500</td> <td>hrs/yr</td> </tr> <tr> <td>Total Annual Electricity Consumption Utilities + DG Sets/ GG Sets</td> <td>998736</td> <td>kWh</td> </tr> <tr> <td>Built up area (Area of the building - Basement and Parking)</td> <td>11000</td> <td>sqm</td> </tr> <tr> <td>EPI</td> <td>91</td> <td>kWh/sqm/yr</td> </tr> <tr> <td>AAHEPI</td> <td>36.32</td> <td>Wh/sqm/h</td> </tr> </table>	Annual Electricity Consumption, purchased from utilities	973569	kWh	Annual Electricity Consumption, through Diesel Generating sets	25167	kWh	Total built up area of the building	18000	sqm	Parking and Basement Area	7000	sqm	Annual Working hours	2500	hrs/yr	Total Annual Electricity Consumption Utilities + DG Sets/ GG Sets	998736	kWh	Built up area (Area of the building - Basement and Parking)	11000	sqm	EPI	91	kWh/sqm/yr	AAHEPI	36.32	Wh/sqm/h
Annual Electricity Consumption, purchased from utilities	973569	kWh																										
Annual Electricity Consumption, through Diesel Generating sets	25167	kWh																										
Total built up area of the building	18000	sqm																										
Parking and Basement Area	7000	sqm																										
Annual Working hours	2500	hrs/yr																										
Total Annual Electricity Consumption Utilities + DG Sets/ GG Sets	998736	kWh																										
Built up area (Area of the building - Basement and Parking)	11000	sqm																										
EPI	91	kWh/sqm/yr																										
AAHEPI	36.32	Wh/sqm/h																										

L2	<p>In the cast house of an Aluminium smelting plant, there are two Billet Casting Machines. Holding cum Melting furnaces are used to meet the molten metal requirement of the Billet Casting Machine and the capacity of these furnaces are 40 Tonnes each.</p> <p>One of the lines has fuel oil fired Holding cum Melting furnace and the other line has Electrical melting cum holding furnace, operated using electricity from the captive power plant.</p> <p>Evaluate whether fuel oil fired furnace is economical or electrical furnace, with respect to operating energy cost in Rs./tonne.</p> <table border="1" style="width: 100%;"> <tr> <td>1. Specific Oil Consumption</td> <td>:</td> <td>26 Ltr/T</td> </tr> <tr> <td>2. Cost of Furnace Oil</td> <td>:</td> <td>38 Rs./ltr</td> </tr> <tr> <td>3. Calorific Value of F.O</td> <td>:</td> <td>10000 kCal/Kg</td> </tr> <tr> <td>4. Efficiency of FO fired melting cum holding furnace</td> <td>:</td> <td>65%</td> </tr> <tr> <td>5. Efficiency of electrical melting and holding furnace</td> <td>:</td> <td>85%</td> </tr> <tr> <td>6. Cost of electricity from Captive Power Plant</td> <td>:</td> <td>3.75 Rs./kWh</td> </tr> <tr> <td>7. Density of Furnace Oil</td> <td>:</td> <td>0.95 kg/ltr</td> </tr> </table>	1. Specific Oil Consumption	:	26 Ltr/T	2. Cost of Furnace Oil	:	38 Rs./ltr	3. Calorific Value of F.O	:	10000 kCal/Kg	4. Efficiency of FO fired melting cum holding furnace	:	65%	5. Efficiency of electrical melting and holding furnace	:	85%	6. Cost of electricity from Captive Power Plant	:	3.75 Rs./kWh	7. Density of Furnace Oil	:	0.95 kg/ltr
1. Specific Oil Consumption	:	26 Ltr/T																				
2. Cost of Furnace Oil	:	38 Rs./ltr																				
3. Calorific Value of F.O	:	10000 kCal/Kg																				
4. Efficiency of FO fired melting cum holding furnace	:	65%																				
5. Efficiency of electrical melting and holding furnace	:	85%																				
6. Cost of electricity from Captive Power Plant	:	3.75 Rs./kWh																				
7. Density of Furnace Oil	:	0.95 kg/ltr																				

L2 S	Solution:																
	<table border="1" style="width: 100%;"> <thead> <tr> <th>Description</th> <th>Value</th> </tr> </thead> <tbody> <tr> <td>Existing Specific Oil Consumption (Ltr/T)</td> <td>26</td> </tr> <tr> <td>Cost of Furnace Oil (Rs./ltr)</td> <td>38</td> </tr> <tr> <td>Calorific Value of F.O (kCal/Kg)</td> <td>10000</td> </tr> <tr> <td>Efficiency of FO fired melting cum holding furnace (%)</td> <td>65%</td> </tr> <tr> <td>Efficiency of Electrical Melting and Holding Furnace (%)</td> <td>85%</td> </tr> <tr> <td>Cost with F.O Heating (Rs./T)</td> <td>26X 38= 988</td> </tr> <tr> <td>Useful heat requirement (kCal/T)</td> <td>=26X0.95X10000X0.65</td> </tr> </tbody> </table>	Description	Value	Existing Specific Oil Consumption (Ltr/T)	26	Cost of Furnace Oil (Rs./ltr)	38	Calorific Value of F.O (kCal/Kg)	10000	Efficiency of FO fired melting cum holding furnace (%)	65%	Efficiency of Electrical Melting and Holding Furnace (%)	85%	Cost with F.O Heating (Rs./T)	26X 38= 988	Useful heat requirement (kCal/T)	=26X0.95X10000X0.65
Description	Value																
Existing Specific Oil Consumption (Ltr/T)	26																
Cost of Furnace Oil (Rs./ltr)	38																
Calorific Value of F.O (kCal/Kg)	10000																
Efficiency of FO fired melting cum holding furnace (%)	65%																
Efficiency of Electrical Melting and Holding Furnace (%)	85%																
Cost with F.O Heating (Rs./T)	26X 38= 988																
Useful heat requirement (kCal/T)	=26X0.95X10000X0.65																

	=1,60,550
Equivalent Electricity input (kWh/T)	= 1,60,550/(0.85X860) = 219.63
Cost with electrical heating (Rs./t)	=219.63 X 3.75 = 823.61
Cost advantage with electrical heating (Rs./T)	= 988 – 823.61 = 164.39
Electrical heating is found more economical.	

.....End of Section II.....

Section - III: LONG NUMERICAL QUESTIONS

Marks: 4 x 20 = 80

- i. Answer all **Four** questions
- ii. Each question carries **TWENTY** marks

N1	<p>A process plant is planning to install a 5 MW gas turbine cogeneration system with 12 TPH waste heat boiler to meet the power and steam demand of the plant.</p> <p>Presently the process steam demand of 14 TPH is met by the gas fired boiler and the plant electricity demand is met from the grid.</p> <p>The co-gen plant will operate at 90% electrical capacity to meet the entire power requirement of the plant and simultaneously supply 11 TPH of process steam requirement. The balance 3 TPH of process steam has to be supplied from the existing gas fired boiler, which is operating at 86% efficiency on NCV basis.</p> <p>If the investment for new 5 MW Co-Gen plant is Rs.30 Crores, calculate the Net Annual savings and payback period.</p> <p>Additional data:</p> <p>Operating Hours per year : 8000 hr NCV of Natural Gas : 8700 kcal/sm³ Cost of Natural Gas : Rs.12/sm³ Heat rate of gas turbine on NCV : 3050 kcal/kwh Cost of electricity from grid supply : Rs.9 /kwh Enthalpy of steam : 665 kcal/kg Feedwater temperature : 85 °C Expenditure towards depreciation & interest : Rs.500 Lakhs/Annum Expenditure for consumables & maintenance of co-gen plant: Rs 200 Lakhs/Annum</p>
N1 S	<p>Solution:</p> <p>Existing System:</p> <p>Annual Electricity Requirement of the plant from the grid = 5000 x 0.9 x 8000 = 36000000 kWh/yr</p> <p>Annual Steam Requirement from Gas fired boiler = 14 x 8000 = 112000 TPY</p> <p>Existing Annual Electrical Energy cost through Grid Supply = (36000000 x 9)/10⁵ = Rs.3240 Lakhs</p> <p>Existing Gas Fired Boiler Evaporation Ratio = (8700x 0.86)/(665 – 85) = 12.9 kgs Steam/sm³ gas</p>

Annual Gas Requirement for the boiler = $(112000 \times 1000)/12.9$
 = 8682171 sm³/yr

Cost of Steam from Gas Fired Boiler = 12/12.9
 = Rs.0.93 per kg steam
 = Rs.930/ton

Total Steam cost from gas fired boiler = $(930 \times 14 \times 8000)/10^5$
 = Rs.1041.6 Lakhs/yr

Total Cost of Grid Electricity plus gas for Steam = (3240 + 1041.6)
 = Rs.4281.6 Lakhs/yr

Proposed System:

Annual Electricity Requirement of the plant from the grid = $5000 \times 0.9 \times 8000$
 = 36000000 kWh/yr

Annual Steam Generation from Co-Gen plant = 11 x 8000
 = 88000 TPY

Power Generation from Co-Gen plant = 5000×0.9
 = 4500 kW

Heat rate of Gas Turbine of Co-Gen plant = 3050 kcal/kWh

Gas requirement for generation of 4500 kW for Co-Gen Plant = $(3050 \times 4500)/8700$
 = 1577.58 sm³/hr
 = 1577.58 x 8000 hrs
 = 12620640 sm³ /yr

Fuel cost for Co-gen plant = $(1577.58 \times 8000 \times 12)/10^5$
 = Rs.1514.5 Lakhs/Annum

Total Cost of Co-Generation (A) = (1514.5 + 500 + 200)
 = Rs.2214.5 Lakhs/yr

Electricity cost from Co-Gen Plant = $(2214.5 \times 10^5)/(4500 \times 8000)$
 = Rs.6.15/kWh

Cost Differential Between Grid and Co-Gen Power = 9 – 6.15
 = Rs.2.85/kWh

Gas for additional 3 TPH steam to be supplied from the gas fired boiler = $(3000/12.9) \times 8000$
 = 1860465 sm³

Cost of gas for additional 3 TPH steam to be supplied from the gas fired boiler = $3 \times 930 \times 8000$
 = Rs. 223.2 Lakhs

Additional gas to be purchased with Co-gen Plant and boiler = $(12620640 + 1860465) - (8682171)$
 = 5798934 sm³/yr

Overall Cost with Co-Generation system including additional steam from gas fired boiler = 2214.5 + 223.2
 = Rs. 2437.7 Lakhs

	<p>Net Annual savings with Co-Gen plant = 4281.6 – 2437.7 = Rs. 1843.9 Lakhs/yr</p> <p>Payback period = 3000/ 1843.9 = 1.63 years or 19.5 months</p>																								
N2	<p>In a chemical plant after meeting all the steam requirements, it was found that there was an excess steam of 10 MT/hr at 8.5 bar(g) from a waste heat boiler, which is presently being condensed through Air fin fan cooler.</p> <p>The chemical plant is having a chilling load of 2400 TR which is met by centrifugal chillers with a COP of 4.4.</p> <p>Based on the recommendation of an energy audit, the management would like to review the scheme of installing absorption chillers. Part of the refrigeration load will be met by a double effect absorption chiller (VAM) with a COP of 1.2, utilizing the excess waste steam. Any additional steam required has to be supplied by the existing fuel fired boiler at a cost of Rs. 1200 /T of steam. The existing cooling towers in the plant have adequate capacity to absorb the higher quantity of heat rejection from the absorption chillers.</p> <table> <tr> <td>Latent heat of steam at 8.5 bar(g)</td> <td>: 479 kcal/kg</td> </tr> <tr> <td>COP of double effect absorption chiller</td> <td>: 1.2</td> </tr> <tr> <td>Centrifugal chiller motor efficiency</td> <td>: 94%</td> </tr> <tr> <td>Electricity cost</td> <td>: Rs. 8/kWh</td> </tr> <tr> <td>Cooling Water cost including pumping energy and chemicals</td> <td>: Rs.3/m³</td> </tr> <tr> <td>CW inlet temperature with VAM</td> <td>: 34 deg. C</td> </tr> <tr> <td>CW outlet temperature with VAM</td> <td>: 42 deg. C</td> </tr> </table> <table> <tr> <td>Volumetric flow rate through air fin fan cooler</td> <td>: 50 m³/sec</td> </tr> <tr> <td>Fan differential static pressure</td> <td>: 100 mmWC</td> </tr> <tr> <td>Fan eff.</td> <td>: 70%</td> </tr> <tr> <td>Fan motor Eff.</td> <td>: 92%</td> </tr> <tr> <td>Annual operating hours</td> <td>: 8000 hrs</td> </tr> </table> <p>Calculate :</p> <ol style="list-style-type: none"> The air fin cooler fan motor input power (kW) (2.5 Marks) The centrifugal chiller motor input power (kW) (2.5 Marks) The additional steam requirement for double effect chiller (kg/hr) (5 Marks) The additional heat load on cooling tower due to double effect chiller in (kcal/hr) (5 Marks) The net annual monetary benefit of entire scheme. (Rs. Lakhs/year) (5 Marks) 	Latent heat of steam at 8.5 bar(g)	: 479 kcal/kg	COP of double effect absorption chiller	: 1.2	Centrifugal chiller motor efficiency	: 94%	Electricity cost	: Rs. 8/kWh	Cooling Water cost including pumping energy and chemicals	: Rs.3/m ³	CW inlet temperature with VAM	: 34 deg. C	CW outlet temperature with VAM	: 42 deg. C	Volumetric flow rate through air fin fan cooler	: 50 m ³ /sec	Fan differential static pressure	: 100 mmWC	Fan eff.	: 70%	Fan motor Eff.	: 92%	Annual operating hours	: 8000 hrs
Latent heat of steam at 8.5 bar(g)	: 479 kcal/kg																								
COP of double effect absorption chiller	: 1.2																								
Centrifugal chiller motor efficiency	: 94%																								
Electricity cost	: Rs. 8/kWh																								
Cooling Water cost including pumping energy and chemicals	: Rs.3/m ³																								
CW inlet temperature with VAM	: 34 deg. C																								
CW outlet temperature with VAM	: 42 deg. C																								
Volumetric flow rate through air fin fan cooler	: 50 m ³ /sec																								
Fan differential static pressure	: 100 mmWC																								
Fan eff.	: 70%																								
Fan motor Eff.	: 92%																								
Annual operating hours	: 8000 hrs																								

N2 S		Solution:		
a) Motor Input Power of Air Fin Fan Cooler	kW	$(\text{m}^3/\text{s}) \times (\text{mmWC}) / (102) \times (\text{Effy-Fan}) \times (\text{Effy-Motor})$	$(50) \times (100) / (102) \times (0.7) \times (0.92)$	76.12
b) Motor Input Power of centrifugal chiller	kW	$\text{COP} = \text{Ref effect (kcal/hr)} / \text{Input power to chiller (kcal/hr)}$ $= (\text{TR} \times 3024) \text{ kcal/hr} / (\text{kW} \times \text{effy chiller motor}) \times (860 \text{ kcal/hr})$ $\text{kW} = (\text{TR} \times 3024) / (\text{COP}) \times (\text{effy chiller motor}) \times 860$ $\text{kW} = \text{TR} / \text{COP} \times (\text{effy chiller motor}) \times (860/3024)$ $\text{kW} = \text{TR} / (4.4 \times 0.94) (860/3024)$ $\text{kW} = 2400 / (4.4 \times 0.94) (860/3024)$ $= 2400 / 1.176$ Chiller input (absorbed) power = 2040.4 kW		2040.4
C) Additional steam for double effect chiller (kg/hr)				
Total heat required for proposed 2400 TR absorption water chiller	kcal/hr	$\text{COP} = \text{Ref effect (kcal/hr)} / \text{Input energy to chiller (kcal/hr)}$ $\text{Input energy to chiller (kcal/hr)} = \text{Ref effect (kcal/hr)} / \text{COP}$ $\text{Input energy to chiller (kcal/hr)} = 2400 \times 3024 / 1.2$ $= 6048000 \text{ kcals/hr}$		6048000 kcals/hr
Heat available from 10 TPH waste excess steam	kcal/hr	$10 \times 1000 \times 479 = 4790000 \text{ kcals/hr}$		4790000 kcals/hr
Balance heat required from additional steam from regular steam header	kcal/hr	$6048000 - 4790000 = 1258000 \text{ kcals/hr}$		1258000 kcals/hr
Additional steam required from regular steam header	kg/hr	$1258000 / 479 = 2626.3 \text{ kg/hr}$		2626.3 kg/hr
d) Additional heat load on cooling tower, kcal/hr				
Condenser duty for centrifugal chiller	kcal/hr	$\text{Condenser heat duty} = \text{Heat Rejected in Chiller} + \text{Heat of Work by compressor}$ $= (\text{TR} \times 3024) + (\text{TR} \times 3024/\text{COP})$ $= (2400 \times 3024) + (2400 \times 3024 / 4.4)$ $= (2400 \times 3024) \times (1 + (1/4.4))$ $= 8907055 \text{ kcals/hr}$		8907055 kcals/hr
Condenser duty for absorption chiller	kcal/hr	$\text{Condenser heat duty}$ $= \text{Heat Rejected in Chiller} + \text{Thermal energy (steam) input to chiller}$ $= (\text{TR} \times 3024) + (\text{TR} \times 3024/\text{COP})$ $= (2400 \times 3024) \times (1 + (1/1.2)) = 13305600 \text{ kcals/hr}$		13305600 kcals/hr
Additional condenser load	kcal/hr	$13305600 - 8907055 = 4398545 \text{ kcals/hr}$		4398545 kcals/hr
Additional Cooling Water required in condenser	m ³ /hr	$\text{Additional heat load} = (\text{Cooling water in kgs/hr}) \times 1000 \times (\text{Cp of Water}) \times \text{CW delT}$ $\text{Cooling water in m}^3/\text{hr} = (\text{Additional heat load}) / (1000 \times 1 \times (42-34))$ $= (4398545) / (1000 \times 1 \times (42-34))$ $= (4398545) / (8000)$ $= 549.82 \text{ m}^3/\text{hr}$		549.82 m ³ /hr
Additional Cooling water cost due to double effect chiller	Rs/hr	$= 549.82 \times 3 = 1649.46$		1650 Rs./hr
e) Annual monetary benefit of entire scheme,	Rs. Lak/year	$= ((76.12 + 2040.4) \times 8000 \times 8) - ((2626.3 / 1000) \times 8000 \times 1200) - (1650 \times 8000)$ $= 135457280 - 25212480 - 13200000$ $= 97044800/10^5$ $= 970.45 \text{ Lakhs/Year}$		970.45 Lakhs/Year

N3		A Shopping mall is operating with a centralized 120 TR chiller. The mall is in operation for 4500 hours in a year. The average energy cost is Rs.9/kWh. The details of the chiller plant is given below:		
		Equipment	Load Current in Amps	Operating Power Factor
		Chiller Compressor	135	0.9

Condenser Pump	32	0.88
Chiller Pump	21	0.9
CT Fan	20	0.65

Note: All the motors are three Phase induction motors and operating at 415 Volts

Efficiency of compressor Motor : 92 %
 Temperature difference across chiller : 4.5° C
 Chilled Water Flow : 23 Lit/s
 Head Developed by Chiller Pump : 35 m
 Condenser Water Flow : 41 Lit/s
 Head Developed by condenser Pump : 30 m

Calculate the following for the existing system:

1. Power Consumed by Chiller Compressor, Chiller Pump, Condenser Pump and CT Fan (3 Marks)
2. TR Delivered by the system (3 Marks)
3. COP of chiller (3 Marks)
4. kW/TR for the chilling plant (2 Marks)
5. Combined efficiency of chiller Pumps and condenser Pumps (3 Marks)

The management has decided to replace the condenser and chiller pumps with efficient pumps. The combined efficiency of motor and pump in both the cases is 65 %.

In addition the condenser has been cleaned resulting in 10 % energy reduction in chiller Power consumption.

Calculate the following after the above modification:

6. New kW/TR for the chilling plant (3 Marks)
7. Annual Energy saving and Monetary savings. (3 Marks)

N3 S

Solution:

1. Power Consumption

Power Consumption of compressor Motor: $1.732 \times 415 \times 135 \times 0.9 = 87.33 \text{ kW}$
 Power Consumption of condenser pump Motor : $1.732 \times 415 \times 32 \times 0.88 = 20.24 \text{ kW}$
 Power Consumption of chiller pump Motor : $1.732 \times 415 \times 21 \times 0.9 = 13.58 \text{ kW}$
 Power Consumption of CT Fan Motor : $1.732 \times 415 \times 20 \times 0.65 = 9.34 \text{ kW}$
 Total Power consumption of chiller Plant : $87.33+20.24+13.58+9.34 = 130.5 \text{ kW}$

2. TR Delivered by the Chiller Plant:

$=m \cdot C_p \cdot \Delta T$
 $= (23 \times 3600) \times 1 \times 4.5 = 372600 \text{ Kcal/hr}$
 TR Delivered = $372600 \text{ Kcal} / 3024 = 123.2 \text{ TR}$
 COP = Refrigeration effect / Input power to compressor = $(372600) / (87.33 \times 0.92 \times 860) = 5.4$
 Overall Chiller Plant, kW/TR = $130.5 / 123.2 = 1.059$
 Combined efficiency of Chiller pumps = LKW/Power Drawn by the pump
 $= 23 \times 35 \times 9.81 / 1000 = 7.89 \text{ kW}$
 $= 7.89 / 13.58 = 58.03 \%$
 Combined efficiency of condenser pumps = LKW/Power Drawn by the pump
 $= 41 \times 30 \times 9.81 / 1000 = 12.06 \text{ kW}$
 $= 12.06 / 20.24 = 59.58 \%$

After Modifications:

Chiller compressor Power = $87.33 \times 0.9 = 78.59 \text{ kW}$
 Chiller Pump power with 65 % Combined Efficiency = $7.89 / 0.65 = 12.13 \text{ Kw}$
 Condenser Pump power with 65 % combined efficiency = $12.06 / 0.65 = 18.55 \text{ kW}$
 Chiller Plant total Power consumption after condenser cleaning and with new pumps =
 $78.59 + 12.13 + 18.55 + 9.34 = 118.61 \text{ kW}$
 Overall Chiller Plant, kW/TR (After Condenser Cleaning and with New efficient Pumps)

$= 118.61 / 123.2 = 0.963 \text{ Kw/TR}$
 Annual Energy Savings for 4500 Hours operation = $(1.059 - 0.963) * 123.2 * 4500 = 53222.4 \text{ kWh}$
 Annual Monetary savings @ Rs 9 /kWh = $53222.4 \times 9 = \text{Rs } 479002$
 (Or)
 Annual Energy Savings for 4500 Hours operation = $(130.5 - 118.6) * 4500 = 53550 \text{ kWh}$
 Annual Monetary savings @ Rs 9 /kWh = $53550 \times 9 = \text{Rs } 481950$

N4 Answer any ONE of the following among four questions given below:

A A coal-based power plant has two units each of 200 MW. Each unit comprises of one turbine and one boiler. Both the units are using the same coal for power generation.

Unit 1 Running Parameters:

Main Steam flow : 670 TPH
 Main Steam Pressure & Temperature: $145 \text{ kg/cm}^2(\text{g}), 540^\circ \text{C}$
 Feed Water Temperature: 150°C
 Ambient Temperature = 30°C
 Fuel (Coal) Analysis:
 Ash : 35%
 Moisture : 13.3%
 Carbon: 40%
 Hydrogen: 2.5%
 Nitrogen: 1.2%
 Oxygen: 7.5%
 Sulphur: 0.5%
 GCV of Coal : 4000 Kcal/kg
 Humidity in ambient air : 0.0199 kg/kg of dry air
 GCV of Bottom Ash = 500 kcal/kg
 GCV of Fly Ash = 200 kcal/kg
 Ratio of Bottom ash to Fly Ash = 1:4
 Oxygen percentage in flue gas at Air heater inlet = 3%
 Specific Heat of Flue Gas = $0.24 \text{ kcal/kg.deg C}$
 CO in Flue gas = 150 ppm
 CO₂ in Flue Gas = 7%
 Heat loss due to radiation & other accounted losses = 0.45%
 Unit 1 Turbine Heat Rate = 2450 kcal/kwh
 Unit 2 Unit Heat Rate = 2790 kcal/kwh
 Average exit flue gas temperature = 170°C
 Load Factor : 75%

Calculate:

1. Unit 1 Boiler efficiency? (10 Marks)
2. Which unit is more efficient? (2 Marks)
3. Find out the difference of coal consumed per day between unit 1 & unit 2 when each unit operates at 75% load. (5 Marks)
4. Calculate the net heat rate of the station with an overall station auxiliary power consumption of 10%. (3 Marks)

N4 A- Sol.

Solution:

1. Theoretical air required = $[11.6 \text{ C} + [34.8 (\text{H}_2 - \text{O}_2/8)] + 4.35 \text{ S}] / 100 \text{ kg air / kg coal}$
 $= [11.6 \times 40 + [34.8 (2.5 - 7.5/8)] + 4.35 \times 0.5] / 100$
 $= 5.20 \text{ kg air / kg coal}$
2. Excess Air, % = $(\% \text{ O}_2) / (21 - \% \text{ O}_2) \times 100$
 $= (3) / (21 - 3) \times 100 = 16.66 \%$
3. Actual Air Supplied (AAS) = $(1 + (16.66/100)) \times 5.20 = 6.06 \text{ kg air / kg coal}$
4. Mass of dry flue gas
 $= ((0.4 * 44) / 12) + (1.2 / 100) + (6.06 * (77 / 100)) + ((6.06 - 5.2) * (23 / 100)) + ((0.5 / 100) * (64 / 32))$
 $= 6.35 \text{ kg dry flue gas / kg coal}$

Boiler Losses:

- a) $L1 = \% \text{ heat loss due to dry flue gases}$
 $= (m \cdot c_p \cdot (T_f - T_a) / \text{GCV of Coal}) \cdot 100$
 $= (6.35 \cdot 0.24 \cdot (170 - 30) / 4000) \cdot 100$
 $= 5.3\%$
- b) $L2 = \% \text{ heat loss due to formation of water from H}_2 \text{ in fuel}$
 $= ((9 \cdot H_2 \cdot (584 + (C_p \cdot (T_f - T_a))) / (\text{GCV of Coal})) \cdot 100$
 $= ((9 \cdot 0.025 \cdot (584 + (0.45 \cdot (170 - 30)))) / (4000)) \cdot 100$
 $= 3.64\%$
- c) $L3 = \% \text{ heat loss due to moisture in fuel}$
 $= ((m \cdot (584 + (C_p \cdot (T_f - T_a)))) / (\text{GCV of Coal})) \cdot 100$
 $= ((0.133 \cdot (584 + (0.45 \cdot (170 - 30)))) / (4000)) \cdot 100$
 $= 2.15\%$
- d) $L4 = \% \text{ heat loss due to moisture in air}$
 $= ((AAS \cdot \text{Humidity} \cdot C_p \cdot (T_f - T_a)) / (\text{GCV of Coal})) \cdot 100$
 $= ((6.06 \cdot 0.0199 \cdot 0.45 \cdot (170 - 30)) / (4000)) \cdot 100$
 $= 0.19\%$
- e) $L5 = \% \text{ heat loss due to partial conversion of C to CO}$
 $= (((\% \text{ CO} \cdot C) / (\% \text{ CO} + \% \text{ CO}_2)) \cdot ((5654 / \text{GCV of Coal})) \cdot 100$
 $= (((0.015 \cdot 0.4) / (0.015 + 7)) \cdot ((5654 / 4000)) \cdot 100$
 $= 0.12\%$
- f) $L6 = \% \text{ heat loss due to ash}$
 Total ash in 1 kg coal = 0.35 kg
 Bottom ash = $0.2 \cdot 0.35 = 0.07 \text{ kg}$
 Fly ash = $0.80 \cdot 0.35 = 0.28 \text{ kg}$
 $\% \text{ heat loss in ash} = (((500 \cdot 0.07) + (200 \cdot 0.28)) / 4000) \cdot 100$
 $= 2.275\%$
- g) $\% \text{ Heat loss due to radiation \& other accounted losses (L7) (Given)} = 0.45\%$

1. Unit 1 Boiler Efficiency:

$$= 100 - (L1 + L2 + L3 + L4 + L5 + L6 + L7)$$

$$= 100 - (5.3 + 3.64 + 2.15 + 0.19 + 0.12 + 2.275 + 0.45)$$

$$= 85.875\% = 85.88\%$$

2. Determination of more efficient unit:

$$\text{Unit heat rate of Unit 1} = (\text{Turbine Heat Rate} / \text{Boiler Efficiency})$$

$$= (2450 / (85.88 / 100))$$

$$= 2852.82 \text{ kcal/kWh}$$

Heat rate of unit 1 (2852.82 kcal/kWh) is higher than heat rate of unit 2 (2790 kcal/kWh), hence unit 2 is more efficient than unit 1.

3. Determination of difference in coal consumption per day for same generation:

$$\text{Coal consumed by Unit 1} = ((\text{Heat rate of unit 1}) \cdot (200 \cdot 1000 \cdot 0.75 \cdot 24)) / (\text{GCV Coal})$$

$$= ((2852.82) \cdot (200 \cdot 1000 \cdot 0.75 \cdot 24)) / (4000)$$

$$= 2567538 \text{ kgs coal/day}$$

$$= 2567.54 \text{ TPD}$$

$$\text{Coal consumed by Unit 2} = ((\text{Heat rate of unit 2}) \cdot (200 \cdot 1000 \cdot 0.75 \cdot 24)) / (\text{GCV Coal})$$

$$= ((2790) \cdot (200 \cdot 1000 \cdot 0.75 \cdot 24)) / (4000)$$

$$= 2511000 \text{ kgs coal/day}$$

$$= 2511 \text{ TPD}$$

$$\text{Difference in coal consumption} = (2567.54 - 2511) \text{ TPD}$$

$$= 56.54 \text{ TPD excess coal consumption by unit 1}$$

4. Net heat rate of the station with an overall station auxiliary power consumption of 10%

	<p>Station Gross Heat Rate = $(2852.82+2790)/2$ $= 2821.4 \text{ kcal/kWh}$</p> <p>Net station heat rate = Gross station heat rate/ (1-% Aux Conspn) $= 2821.4 / (1-0.10)$ $= 3134.9 = 3135 \text{ kcal/kWh}$</p>
N4	OR
B	<p>In a textile process unit, a five chamber stenter is installed for drying the cloth. The hot air used for drying in the stenter is heated by furnace oil fired thermic fluid heater. The production output of the stenter is 70 meter/min. Dried finished cloth is leaving the stenter at 5% moisture & 80 °C temperature, whereas the wet cloth is entering at 30°C & 55% moisture. The stenter is operating for 7000 hours/yr.</p> <p>Towards reducing the fuel consumption in thermopack the management has decided to first take steps to improve the stenter drying efficiency followed by reducing the inlet moisture by mechanical roller squeezing.</p> <ul style="list-style-type: none"> • Cost of Furnace Oil :36 Rs/Lit • GCV of Furnace Oil :10000 kcal/kg • Thermic fluid heater efficiency: 80%. • Average Furnace Oil Consumption rate = 85 litre/hr • Density of Furnace oil = 0.95 kg/litre • Weight of 1 meter of Outgoing dry cloth = 100 gms • The distribution loss in the thermic fluid system is 45000 kcal/hr <p>Calculate:</p> <ol style="list-style-type: none"> 1. Existing Drier Efficiency. (10 Marks) 2. Annual reduction in furnace oil consumption and the monetary savings if the dryer efficiency is improved by 10%? (5 Marks) 3. If the inlet moisture is reduced from 55% to 45%, after improving the dryer efficiency, Calculate the incremental (additional) reduction in furnace oil consumption on an annual basis. (5 Marks)
N4 B-Sol.	<p>Solution:</p> <p>1. Existing Drier Efficiency with 55% inlet moisture</p> <p>Stenter Speed = 70 meter/min Therefore, Dried Cloth Output = 70 meter/min X 100 gm/meter $= 7 \text{ kg/min}$ $= 7*60 \text{ kg/hr} = 420 \text{ kg/hr}$</p> <p>Weight of material output of the dryer on bone dry basis per hour (W) $= 420 * 0.95$ $= 399 \text{ kg/hr}$</p> <p>Therefore, inlet wet cloth flow rate = (Bone dry cloth rate/hr)/ (1-0.55) $= (399/(1-0.55)) = 886.67 \text{ kg/hr}$</p> <p>Therefore, weight of moisture in inlet material per kg of bone-dry basis weight: (m_{in}) $= (886.67-399)/(399) = 1.22 \text{ kg of moisture/ kg of bone dry material}$</p> <p>Weight of moisture in outlet material per kg of bone-dry basis weight: (m_{out}) $= (420-399)/(399) = 0.05 \text{ kg of moisture/ kg of bone-dry material}$</p> <p>Heat input to the dryer (Q_{in})</p> <p>= Heat output of the thermic fluid heater – distribution loss in the thermic fluid system = (Furnace oil consumption rate X density X GCV X Eff) – distribution loss in the thermic fluid sys $= (85*0.95*10000*0.8)-45000$ $= 646000-45000$</p>

$$= 601000 \text{ kcal/hr}$$

Heat Output to the dryer (Q_{in})

$$\begin{aligned} &= (W (m_{in}-m_{out}) [(T_{out}-T_{in}) +540]) \\ &= (399(1.22-0.05) [(80-30)+540]) \\ &= 275430 \text{ kcal/hr} \end{aligned}$$

Therefore, Drier Efficiency

$$\begin{aligned} &= (\text{Heat Output} / \text{Heat Input}) * 100 \\ &= (275430 / 601000) * 100 \\ &= \mathbf{45.8\%} \end{aligned}$$

2. Fuel Savings due to Improved Drier Efficiency by 10% (i.e.,55.8% Eff)

Heat input to the dryer (Q_{in})

$$\begin{aligned} &= (\text{Heat output from the dryer} / \text{new dryer efficiency}) \\ &= 275430 / 0.558 \\ &= 493602.15 \text{ kcal/hr} \end{aligned}$$

Heat loss in the thermic fluid system

$$= 45000$$

$$\begin{aligned} \text{Total heat to supplied by the thermic fluid heater} &= (\text{Heat req for drier} + \text{distribution system loss}) \\ &= 493602.15 + 45000 \\ &= 538602.15 \text{ kcal/hr} \end{aligned}$$

Fuel consumption in thermic fluid heater after improving dryer efficiency

$$\begin{aligned} \text{Operating efficiency of thermic fluid heater is} &= 80\% \\ &= 538602.15/0.8 \\ &= 673252.7 \text{ kcal/hr} \end{aligned}$$

Fuel consumption in liters/hr

$$\begin{aligned} &= 673252.7/(10000*0.95) \\ &= \mathbf{70.87 \text{ lit/hr}} \end{aligned}$$

$$\begin{aligned} \text{Annual FO savings by improving dryer efficiency} &= (85 - 70.87) \times 7000 \text{ hours/yr} \\ &= 98910 \text{ lit/yr} \\ &= 98.91 \text{ kL/yr} \\ \text{Annual Monetary savings} &= 98910 * 36 \\ &= \text{Rs.35,60760/yr} \\ &= \text{Rs.35.61 Lakhs/yr} \end{aligned}$$

3. Incremental annual reduction in furnace oil consumption by reducing the Inlet moisture from 55% to 45%, after improving the dryer efficiency:

Stenter Speed = 70 meter/min

$$\begin{aligned} \text{Therefore, Dried Cloth Output} &= 70 \text{ meter/min} \times 100 \text{ gm/meter} \\ &= 7 \text{ kg/min} \\ &= 7 * 60 \text{ kg/hr} = 420 \text{ kg/hr} \end{aligned}$$

$$\begin{aligned} \text{Weight of material output of the dryer on bone dry basis per hour (W)} \\ &= 420 * 0.95 \end{aligned}$$

$$= 399 \text{ kg/hr}$$

Therefore, inlet wet cloth flow rate = (Bone dry cloth rate/hr)/ (1-0.45)
 $= (399/(1-0.45)) = 725.45 \text{ kg/hr}$

Therefore, weight of moisture in inlet material per kg of bone-dry basis weight: (m_{in})

$$= (725.45-399)/(399) = 0.818 \text{ kg of moisture/ kg of bone dry material}$$

Weight of moisture in outlet material per kg of bone-dry basis weight: (m_{out})

$$= (420-399)/(399) = 0.05 \text{ kg of moisture/ kg of bone-dry material}$$

Heat Output (Load) of the dryer (Q_{out})

$$= (W (m_{in}-m_{out}) [(T_{out}-T_{in}) +540])$$

$$= (399(0.818-0.05) [(80-30) +540])$$

$$= 180794.9 \text{ kcal/hr}$$

Heat input to Drier = Head load/ Improved Drier Efficiency

$$= 180794.9/0.558$$

$$= 324005.16 \text{ kcal/hr}$$

Heat to be supplied by the thermic fluid heater

$$= 324005.16+45000$$

$$= 369005.16 \text{ kcal/hr}$$

Fuel consumption in thermic fluid heater after inlet moisture reduction with improved dryer efficiency:

$$= 369005.16 / (10000*0.95*0.8)$$


$$= 48.55 \text{ lit/hr}$$

Annual incremental FO savings by inlet moisture reduction = $(70.87-48.55) \times 7000$
 $= 22.32 \times 7000$
 $= 156240 \text{ lit/yr}$
 $= 156.24 \text{ kL/yr}$

N4

OR

C The schematic of a Vertical Roller Mill (VRM) used for Raw Meal (RM) grinding in a 7800 TPD cement plant is given below.



The VRM is operating at 260 TPH whereas designed for 250 TPH. The following are the process measurements during a performance assessment study.

Parameters	Value
------------	-------

VRM motor input Power (kW)	2294
RM Fan motor input Power (kW)	1650
RM Fan Motor Efficiency (%)	95%
RMS value of Dynamic Pressure of the gas at Fan inlet (mmWC)	14.5
Pitot Tube Constant (Cp)	0.86
Duct diameter at the fan inlet (m)	3.5
Temperature of gas at fan inlet (°C)	70
Static Pressure at Fan Inlet (before damper) (mmWC)	-710
Static Pressure at Fan Inlet (after damper) (mmWC)	-850
Static Pressure at Fan outlet (mmWC)	30
Density of RM Gas at Fan inlet (kg/m ³)	1.35

- Calculate the specific power consumption of the raw mill (kWh/ton output) (2 Marks)
- Specific power consumption of raw mill fan (kWh/ton output). (2 Marks)
- Calculate the raw mill fan efficiency (%). (10 Marks)
- The damper control was replaced by a VFD control, which resulted in an excess flow at 50 Hz operation. The flow was brought back to normal by reducing the VFD frequency to 40 Hz. Calculate the savings in fan power consumption. (Ignore the VFD losses) (6 Marks)

N4C-Sol.

Soln:

a.	<p>Specific Power Consumption of RM (kW/Ton) (Raw Mill motor input Power/ Mill Output) = 2294 kW/ 260 TPH = 8.8 kWh/ton</p>
b.	<p>Specific power consumption of RM Fan (kW/Ton) (Raw Mill fan motor input Power/ Mill Output) =1650 kW/ 260 TPH =6.35 kWh/ton</p>
c.	<p>Fan Efficiency Correction Density (ρ_2)= (ρ_1) * ($\frac{P_1}{P_2}$) * ($\frac{T_1}{T_2}$) = 1.35*((10323-850)/10323) * (273/(273+70))=0.986 kg/m³</p> <p>Velocity of Gas at Fan Inlet = $C_p \cdot \sqrt{2 \cdot g \cdot P_{dymc} / \rho_2}$ = .86 * $\sqrt{2 \cdot 9.81 \cdot 14.5 / 0.986}$ = 14.6 m/s</p> <p>Area of the duct = $\pi \cdot D^2 / 4$ = 3.14 * 3.5 * 3.5 / 4 = 9.6163 m²</p> <p>Flow at fan Inlet, (m³/sec) = Vel (m/sec) * area (m²) = 14.6 * 9.616 = 140.3936 m³/sec</p>

Fan Static Efficiency=
 $\text{Flow (m}^3/\text{sec)} * \text{head (mmWC)} / (102 * \text{fan Motor Power(kW)} * \text{Motor Eff}(\%))$
 $= 140.4 * (30+850) / (102 * 1650 * 95\%) * 100$
 $= 77.3\%$

D. By using Affinity Law, $(P_1/P_2) = (N_1^3/N_2^3) = (Hz_1^3 / Hz_2^3)$
 $(1650 \text{ kW} / P_2) = (50^3/40^3)$
 $P_2 = (1650 \times 40^3) / 50^3$
 $P_2 = (1650 \times 64000) / 125000$
 $P_2 = 844.8 \text{ kW} = 845 \text{ kW}$
 Savings in fan power consumption = 1650 – 845 = 805 kW.

N4

D A commercial building is using vapor compression refrigeration (VCR) chiller for meeting its cooling requirement.

The following data pertaining to building is given below.

Outdoor Conditions:

DBT: 35 deg.C

Humidity: 24.0 g of water/kg of dry air

Desired indoor conditions:

DBT: 23 deg.C

RH: 50%

Humidity: 9.3 g of water/kg of dry air

Other data

Total wall surface area: 140 m²

Total window area: 50 m²

Roof area: 15 X 25 m²

U-factor (Wall): 0.34 W/ m²-K

U-factor (Roof): 0.32 W/ m²-K

U-factor (Window): 3.6 W/m²-K

CLTD at 17:00 hrs for Wall: 12 deg.C

CLTD at 17:00 hrs for Roof: 44 deg.C

CLTD at 17:00 hrs for Window: 7 deg.C

SCL at 17:00 hrs for Glass window: 605 W/m²

Shading coefficient of window: 0.75

Space is occupied from 09:00 to 17:00 hrs by 30 people doing moderately active work

Sensible heat gain / person: 75 W

Latent heat gain / person: 55 W

CLF for people : 0.9

LED light in space: 12 W/m²
 CLF for lighting: 0.9
 Coffee maker latent heat: 600 W
 Coffee maker sensible heat: 1800 W
 Sensible heat of Computer and other office equipments: 3.4 W/m²
 Air changes /hr of infiltration: 2
 Height of building: 3.5 m
 Chiller COP: 3.5
 Chiller motor Efficiency: 95%
 Power cost: Rs. 7.5/kWh
 Working days: 250 days/year
 Operating hours : 8 hours/day

Calculate the following:

- a) External heat gain of the building (kW) **(5 Marks)**
- b) Internal heat gain of the building (kW) **(6 Marks)**
- c) Total cooling load of building (kW) **(3 Marks)**
- d) Additional cost Rs. Lakhs/year, if air change rate/hr is increased to 4. **(6 Marks)**

N4D-Sol.	a) External Heat Gain:		
	Conduction heat gain through wall	= $0.34 \times (140-50) \times 12$ = 367.2	W
	Conduction heat gain through roof	= $0.32 \times (15 \times 25) \times 44$ = 5280	W
	Conduction heat gain through window	= $3.6 \times 50 \times 7$ = 1260	W
	Solar radiation through window	= $605 \times 50 \times 0.75$ = 22687.5	W
	Total external heat gain	= $(367.2+5280+1260+22687.5) / 1000$ = 29.6	kW
	b) Internal Heat Gain:		
	Sensible heat gain from people	= $30 \times 75 \times 0.9$ = 2025	W
	Latent heat gain from people	= 30×55 = 1650	W
	Total heat gain from people	= $2025 + 1650$ = 3675	W
	Total heat gain from lighting	= $12 \times (15 \times 25) \times 0.9$ = 4050	W
	Heat gain from coffee maker	= $600 + 1800$ = 2400	W
	Heat gain from computers and other office equipments	= $3.4 \times (15 \times 25)$ = 1275	W
Total heat gain from equipment	= $2400 + 1275$ = 3675	W	
Air infiltration flow rate	= $((15 \times 25) \times (3.5)) \times (2.0) / 3600$ = 0.729	m ³ /sec	

Sensible heat gain from air infiltration	= 1210 x 0.729 x (35-23) = 10585	W
Latent heat gain from air infiltration	= 3010 x 0.729 x (24-9.3) = 32256	W
Total heat gain from air infiltration	= 10585 + 32256 = 42841	W
Total internal heat gain	= (3675+4050+3675+42841)/1000 = 54.24	kW
c) Total cooling load of building	= (29.6+54.24) = 83.84	kW
d) Additional Cost due to air change rate:		
New Air infiltration flow rate	= (15 x 25) x (3.5)* (4.0)/3600 = 1.458	m ³ /sec
New sensible heat gain from air infiltration	= 1210 x 1.458 x (35-23) = 21170.1	W
New latent heat gain from air infiltration	= 3010 x 1.458 x (24-9.3) = 64512.1	W
Total heat gain from air infiltration	= 21170.1+64512.1 = 85682.2	W
Additional cooling load due to change in air change rate/hr	=(85682.2-42841)/1000 = 42.8	kW
Additional cost due to change in air change rate/hr	= $\frac{(\frac{42.8}{3.5 \times 0.95}) \times 8 \times 250 \times 7.5}{10^5}$ = 1.9	Rs. Lakhs/year

.....End of Section III.....