

**22nd NATIONAL CERTIFICATION EXAMINATION
FOR
ENERGY MANAGERS & ENERGY AUDITORS - JULY, 2022**

PAPER – 4 : ENERGY PERFORMANCE ASSESSMENT FOR EQUIPMENT AND UTILITY SYSTEMS

Date : 31.07.2022 Timings : 14:00-16:00 HRS Duration : 2 HRS Max. Marks : 100

Section - I: BRIEF QUESTIONS

Marks: 10 x 1 = 10

- (i) Answer all **Ten** questions
(ii) Each question carries **One** mark

1	Ideally the flow capacity of a forced draft fan of a pulverised fuel boiler operating on balanced draft when compared to an Induced draft fan is _____.	Lower/ Higher/ Same	Lower
2	If waste heat delivered to the heat pump is 3440 kcal/hr and power consumed by the heat pump compressor is 1.5 KW then the heat developed by heat pump is 6.6 kW.	True/False	False
3	Lower the terminal temperature difference in a steam condenser of a turbine _____ is the heat transfer rate between steam and cooling water.	Lower/Higher	Higher
4	In an extraction back pressure cogeneration system, higher the steam flow through the turbine extractions, lower is the energy utilisation factor.	True/False	False
5	Rated power of motor is power consumed by motor.	True/False	False
6	NPSH required of centrifugal pump increases with flow.	True/False	True
7	The lower the dew point of air the higher is the moisture in air.	True/False	False
8	In a boiler, higher the % of CO ₂ in flue gas, the better is the combustion efficiency.	True/False	True
9	Air infiltration in an air-conditioned building, will increase both the latent heat and sensible heat load.	True/False	True
10	The turbine cycle efficiency of a thermal power plant will increase with decrease in inlet cooling water temperature to the condenser.	True/False	True

..... **End of Section - I**

Section - II: SHORT NUMERICAL QUESTIONS

Marks: 2 x 5 = 10

L1	<p>A process plant is importing 25 TPH of steam at 20 bar(g) pressure and reduces to 5 bar(g) through PRDS. The plant is also operating a motor driven gas compressor drawing a power of 900 kW. During an energy audit, it was suggested to evaluate the scheme of installing back pressure steam turbine instead of PRDS for driving the gas compressor.</p> <p>Calculate the steam required for operating the back pressure turbine and hourly monetary savings.</p> <p>Turbine power generation per unit of inlet steam: 0.045 kWh/kg steam</p> <p>Power cost : Rs.9.0/kWh</p> <p>Import steam cost : Rs.3500/MT</p>
-----------	--

L1 Sol	Steam required for back pressure turbine	= (900/0.045)/1000 = 20 TPH
	Hourly monetary saving	= (900 x 9) = Rs.8,100
L2	<p>A medium size edible oil plant planning to install a thermic fluid heating system for their process requirements. The suggested operating parameters of thermic fluid system are given below:</p> <p><u>Heat output data:</u></p> <p>Flow rate of thermic fluid : 60 m³/h Inlet temperature of thermic fluid : 210 °C Outlet temperature of thermic fluid : 230 °C Flue gas exit temperature of thermic fluid heater: 275 °C Specific heat of thermic fluid : 2.233 kJ/kg °C Density of the thermic fluid : 826 kg/m³</p> <p>The plant has to choose either oil or briquettes as a fuel. The following is the additional data:</p> <p>Efficiency of oil fired thermic fluid heater: 80% Efficiency of briquette fired thermic fluid heater: 65% GCV of fuel oil : 10000 kcal/kg Cost of oil :Rs.70/kg GCV of briquettes : 3200 kcal/kg Cost of briquettes : Rs.8/kg</p> <p>a) Calculate the heat load of the system in kcal/hr 3 marks b) As an energy auditor, based on operating cost, which system will you recommend? 2 marks</p>	
L2-Sol	<p>Solution:</p> <p>Heat load of the system: Mass of thermic fluid = 60 x 826 = 49,560 kg/hr</p> <p>$Q = mcp\Delta T$ = 49,560 x 2.233/4.186 x (230-210) = 528750.50 kcal/hr</p> <p>Operating Cost:</p> <p>1. Fuel oil quantity required = 528750 / (10000 x 0.8) = 66.09 kg/hr Operating cost with fuel oil = 66.09 x 70 = Rs.4626.3 /hr</p> <p>2. briquettes required = 528750.50 / (3200 x0.65) = 254.21 kg/hr Operating cost with briquettes = 254.21 x 8 = Rs.2033.68/hr</p> <p>As an energy auditor based on the operating cost, I recommend briquettes as fuel for thermic fluid heater system.</p>	

..... End of Section - II

Section - III: LONG NUMERICAL QUESTIONS

Marks: 4 x 20 = 80

- (i) Answer all the **Four** questions
(ii) Each question carries **Twenty** marks

N-1 (N1-A) A large water tube boiler was assessed for its performance. The operating conditions and design conditions of the boiler are given below.

Parameter	Unit	Design conditions	Operating conditions
Steam generation	Tons/hr	210	210
Steam pressure	Kg/cm ²	100	100
Steam temperature	°C	440	440
Coal firing rate	Tons/hr	43	--
Flue gas temp, at the inlet of Air preheater	°C	370	--
Flue gas temp, at the outlet of Air preheater	°C	145	165
Excess air at Air preheater inlet	%	20%	25%
Excess air at preheater outlet	%	--	44.8%
% Dry flue gas heat loss	%	4.67	--
GCV of coal	Kcal/kg	3585	3240
Specific heat of flue gas	Kcal/kg k	0.23	0.23
Dry flue gas flow at air preheater outlet	Tons/hr	--	324
Ambient temperature	°C	36	37

Using the above data calculate the following:

- Heat loss in dry flue gas in kcal /hr at design conditions **(4 Marks)**
- Heat loss in dry flue gas in kcal/hr at operating conditions **(3 Marks)**
- Increase in operating coal consumption in Tons/hr w.r.t design due to higher dry flue gas loss considering boiler efficiency of 86%. **(2 Marks)**
- Additional expenditure to meet increased heat loss towards coal for 7000 hours of operation of boiler in a year at a coal cost of Rs 9500/Ton. **(3 Marks)**
- Air leakage in Air preheater in % during operation **(3 Marks)**

(N1-B) Calculate the following for the given operating parameters

- Effectiveness of air preheater **(3 Marks)**
- Actual mass of air supplied in kg of air/kg of fuel the following operating parameters: **(2 Marks)**

S.NO	Description	Design	Operating
1.	Generation	500 MW	440 MW
2.	Flue Gas temperature inlet (°C)	356	315
3.	Flue Gas temperature outlet (°C)	147	178
4.	Air temperature inlet (°C)	36	40
5.	Air temperature outlet (°C)	316	294
6.	Measured O ₂ % in flue gas	3.56	4.56
7.	Theoretical air kg of air/kg of fuel	5.0	5.0

N1-S

A.

- Calculation of dry flue gas heat loss at design conditions
 We have,
 % Heat loss in dry flue gas= 4.67% = $m C_p (T_f - T_a) / \text{GCV of coal}$ ------(i)
 m= mass of dry flue gas, kg/kg of coal
 C_p=Specific heat of flue gas, kcal/kg k=0.23
 T_f=temp of flue gas deg,C=145
 T_a=Ambient temp. Deg,C=36
 GCV=3585 kcal/kg
 Substituting the values in equation (i)

$$4.67/100 = m \times 0.23 \times (145-36)/(3585)$$

$m = 6.68$ kg of dry flue gas/kg of coal (or) $m = 6.67$ kg of dry flue gas/kg of coal

coal firing rate = 43×1000 kg/hr

mass flow rate of dry flue gas = $6.68 \times 43 \times 1000 = 287240$ kg/hr = M

$$\text{Heat loss in dry flue gas} = M \times C_p \times (T_f - T_a) = 287240 \times 0.23 \times (145 - 36) \\ = 7201106.8 \text{ kcal/hr (or) } 7190326 \text{ kcal/hr}$$

Alternate solution:

$$= 4.67 \times 3585/100$$

Flue gas loss = 167.41 kcal/kg

Design fuel firing rate = 43 TPH

$$= 43 \times 1000 \times 167.41$$

$$= 7198630 \text{ kcal/hr}$$

ii) Flue gas Heat loss at operating conditions = $M \times C_p \times (T_f - T_a)$ ----- (ii)

$M = 324 \times 1000$ kg/hr

$C_p = 0.23$ kcal/kg K

$T_f = 165$ deg C

$T_a = 37$ deg.C

Substituting the values in equation (ii)

$$\text{Flue gas heat loss} = 324 \times 1000 \times 0.23 \times (165 - 37) = 9538560 \text{ kcal/hr} \text{-----ANS}$$

iii) Increase in dry flue gas heat loss = $(9538560 - 7201106.8)$

$$= 2337453.2 \text{ kcal/h} \text{-----ANS}$$

Coal equivalent of heat loss = $2337453.2/3240$ kcal/kg = 721.4 kg/h

Considering boiler efficiency of 86% ,

Coal equivalent = $721.4/0.86 = 838.8$ kg/hr = 0.8388 Tons/hr-----ANS

iv) Additional expenditure to be incurred due increase in dry flue gas heat loss/year =

$$= 0.8388 \times 7000 \times 9500 \text{ Rs/ton} = \text{Rs } 557.80 \text{ Lakhs} \text{-----ANS}$$

v) Air preheater leakage = $(O_2 \% \text{ in flue gas leaving APH} - O_2 \% \text{ in flue gas entering APH}) / (21 - O_2 \% \text{ in flue gas leaving APH})$ ----- (iii)

25% and 44.8% excess air corresponds to 4.2% O_2 and 6.5% O_2 respectively as calculated from the equation, Excess Air = $\%O_2 / (21 - \%O_2)$

From equation (iii)

$$\% \text{ APH leakage} = (6.5 - 4.2) / (21 - 6.5) \times 100 = 15.86\% \text{-----ANS}$$

N1-B-S

Solution:

i). APH Effectiveness (4 Marks)

$$= (\text{Air temp APH out} - \text{Air Temp APH in}) / (\text{Flue Gas temp. APH in} - \text{Air temp. APH in}) \times 100$$

$$= (294 - 40) / (315 - 40) \times 100$$

$$= 92.36 \%$$

ii). Actual mass of air supplied in kg of air/kg of fuel (1 Mark)

$$\text{Excess air} = O_2\% / (21 - O_2\%) = 4.56\% / (21 - 4.56\%) \times 100 = 27.73 \%$$

AAS = $(1 + EA/100) \times \text{Theoretical Air}$

$$= (1 + 0.2773) \times 5$$

$$= 6.386 \text{ kg of air/ kg of fuel}$$

N-2 a) Two stage reciprocating belt driven air compressor is designed for the following conditions.

Air inlet pressure	: 1.033 kg/cm ² (a)
Air inlet temperature	: 30 °C
Compressor discharge pressure	: 7.0 kg/cm ² (g)
Isothermal efficiency	: 60%
Free air delivery	: 11.67 m ³ /min
Motor efficiency	: 85%
Belt power transmission efficiency	: 97%


Based on the above data calculate:

- (i) Power input to the motor (5 Marks)
- (ii) Specific power consumption of the compressor in kW/m³/hr (1 Mark)
- (iii) If the discharge air pressure is reduced to 6 kg/cm² g, calculate the reduction in kW (2 Marks)


b) In a chemical plant, a 160 TPH process gas stream is being cooled from 55 deg.C to 35 deg.C through cooling water exchanger. The plant team would like to further cool this process gas stream upto 30 deg.C as the envisaged monetary saving potential is Rs.200 lakhs per annum due to process improvement.

Due to water scarcity, the plant team proposes to completely avoid the usage of existing water cooled heat exchanger and proposes to use air fin fan cooler followed by a water cooled chiller as shown in the schematic.

EXISTING CASE :



PROPOSED CASE :



Specific heat of process stream	: 0.5 kcal/kg-deg.C
COP of chiller	: 4.2
Chiller compressor motor efficiency	: 94%
Range of the chiller cooling tower	: 5°C
Power consumption of Cooling Tower Pump and Fan	: 11 kW
Power cost	: Rs. 9/kWh
CW cost	: Rs.1.2/m ³
Volumetric flow rate through air fin fan cooler	: 300 m ³ /sec
Fan differential static pressure	: 100 mmWC
Fan efficiency	: 70%
Fan motor efficiency	: 95%
Operating hours in year	: 8000 hrs

Calculate the following:

	i) Cooling water flow (m ³ /hr) of existing cooling water exchanger for reducing process gas stream temperature from 55 deg.C to 35 deg.C. (1 Mark)
	ii) Proposed chiller capacity (TR) (3 Marks)
	iii) Circulating cooling water flow for the proposed chiller (m ³ /hr). (3 Marks)
	iv) Power consumption (kW), for the proposed water-cooled chiller and air fin fan cooler (3 Marks)
	v) As an energy auditor economically evaluate the new proposal and give your recommendation. (2 Marks)

N2-S (A)

(i) Power input to motor
 We have Isothermal efficiency = Isothermal power/compressor shaft power = 0.6 -----(1)
 Isothermal power = $P_1 \times Q_f \times \log_e r / 36.7$ kw------(2)
 Where,

P_1 = Compressor inlet air pressure kg/cm² a = 1.033
 Q_f = FAD m³/min = 11.67 x 60 m³/hr
 $r = P_2/P_1 = (7 + 1.033)/1.033 = 7.776$
 Substituting the values in equation (2) we get
 Isothermal power = $1.033 \times 11.67 \times 60 \times \log_e 7.776 / 36.7 = 40.4$ kw
 From equation(1), 0.6 = 40.4/compressor shaft power
 Compressor shaft power = $40.4 / 0.6 = 67.33$ kW
 Input power to motor = $67.33 / (0.85 \times 0.97) = 81.66$ kW -----ANS

(ii) Specific power consumption = Input power to motor, kW/m³/hr
 = $81.66 / (11.67 \times 60)$
 = 0.1166 kW/(m³/hr) –ANS

(iii) calculation of % Saving in power when discharge pressure reduced to 6 kg/cm² (g)
 NOW, $P_2 = 6 + 1.033$ kg/cm² a
 $P_1 = 1.033$ KG/CM² a
 $r = (6 + 1.033) / 1.033 = 6.8$
 $FAD = 11.67$ m³ /min
 Isothermal power = $(1.033 \times 11.67 \times 60 \times \log_e 6.8) / (36.7)$
 = 37.8 kw
 From equation (1) above,
 Isothermal efficiency = 0.6 = 37.8/compressor shaft power
 Compressor shaft power = $37.8 / 0.6 = 63$ kW
 Motor input power = $63 / (0.97 \times 0.85) = 76.4$ kW
 Saving in power = $(81.66 - 76.41)$
 = 5.25 kW


b)

i)	Cooling water flow rate to existing cooler	= $160 \times 0.5 \times (55-35) / (42-34)$ = 200.0	m ³ /hr
ii)	Total required duty in new scheme	= $160 \times 1000 \times 0.5 \times (55-30) / 10^6$ = 2.00	Gcal/hr
	Heat Duty of Air Fin fan cooler	= $160 \times 1000 \times 0.5 \times (55-35) / 10^6$ = 1.6	Gcal/hr
	Residual duty required through chiller	= $(2.0 - 1.6) \times 10^6 / 3024$ = 132	TR
iii)	Chiller condenser duty	= $132 \times (1 + 1/4.2)$ = 163	TR
		= $163 \times 3024 / 10^6$ = 0.49	Gcal/hr

	Required CW flow for new chiller condenser	$= (0.49 \times 10^6) / \{1.0 \times (5)\} / 1000$ $= 98$	m ³ /hr
iv)	Centrifugal chiller power consumption	$= (132 \times 3024 / 4.2 / 860) / 0.94$ $= 117.6$	kW
	Fan power consumption of Air fin fan cooler	$= 300 \times 100 / (102 \times 0.70 \times 0.95)$ $= 442$	kW
	Power consumption of cooling tower pump and fan	$= 11$ kW	
	Total additional power consumption	$= 117.6 + 442 + 11$ $= 570.6$	kW
v)	Power cost for the proposed scheme	$= 570.6 \times 9 \times 8000 / 10^5$ $= 410.832$	Rs. Lakhs PA
	Process benefit of new scheme	$= 200.0$	Rs. Lakhs PA
	Potential monetary loss of new scheme	$= (200 - (410.832))$ $= -210.83$	Rs. Lakhs PA

Recommendation: Proposed scheme is not viable.

N-3 An effluent treatment plant is treating effluent from nearby industries and treated effluent is recycled back to nearby industries as raw water. The biogas generated from the effluent plant is used in a back pressure co-generation system. The operation details are shown in the schematic and tabulated below:



Steam enthalpy at generation pressure and temperature:	720 kcal/kg
Enthalpy of back pressure steam	: 660 kcal/kg
Turbine efficiency	: 85%
Generator efficiency	: 97%
Gear box efficiency	: 98%
Power generated	: 900 kW
Boiler efficiency	: 75%
Bio gas GCV	: 7000 kcal/sm ³
Capacity of absorption chiller	: 2000 TR
COP of absorption chiller	: 0.8
Efficiency of cooling tower pump	: 75%
Efficiency of cooling tower pump motor	: 93%
Head developed by the pump	: 15 meter

Cooling tower range	: 5°C
Calculate the following:	
i) Steam flow to the turbine in TPH	4 Marks
ii) Steam flow to the chiller in TPH	4 Marks
iii) Steam flow to the process in TPH	2 Marks
iv) Bio gas input to the boiler in sm ³ /hr	4 Marks
v) Calculate the input power drawn by the cooling tower pump in kW	6 Marks

N-3-S	Solution:		
	i)	Heat Output of generator	$= 900 \text{ kW} \times 860 \text{ kcal}$ $= 774000 / (0.97 \times 0.98 \times 0.85)$ $= 957909 \text{ kcal/hr}$ Or $= 900 \text{ kW} / (0.97 \times 0.98 \times 0.85)$ $= 1113.8 \text{ kW} \times 860$ $= 957909 \text{ kcal/hr}$
		Enthalpy drop across the turbine	$= 720 - 660$ $= 60 \text{ kcal/kg}$
		Steam flow to the turbine (m ³)	$= 957909 \text{ kcal/hr} / 60 \text{ kcal/kg}$ $= 15965 \text{ kg/hr or } 15.96 \text{ TPH}$
	ii)	Heat required for the chiller	$= 2000 \times 3024 / (0.8)$ $= 7560000 \text{ kcal/hr}$
		Steam flow to the chiller in TPH	$= 7560000 \text{ kcal/hr} / (660 - 100) \text{ kcal/kg}$ $= 13500 \text{ kg/h or } 13.5 \text{ TPH}$
	iii)	Steam flow to the process in TPH	$= 15.96 - 13.5$ $= 2.46 \text{ TPH}$
	vi)	Biogas consumption:	
		When two liquids of different temperature are mixed in a tank, to calculate the final temperature	$= ((m_1 \times S_1 \times T_1) + (m_2 \times S_2 \times T_2)) / (m_1 \times S_1 + m_2 \times S_2)$ $= (13.5 \times 100 + 2.46 \times 30) / (13.5 + 2.46)$ $= 89.2 \text{ °C}$
		The biogas flow rate, q	$= 15.96 \times 1000 \times (720 - 89.2) / (0.75 \times 7000)$ $= 1917.6 \text{ sm}^3/\text{hr}$
			(or)
			$= (13.5 \times 1000 (720 - 100)) + (2.46 \times 1000 \times (720 - 30)) / (0.75 \times 7000)$ $= 1917.6 \text{ sm}^3/\text{hr}$
	v)	input power drawn by the cooling tower pump	
		Heat rejected by VAM chiller	$= (2000 \times 3024) + 13.5 \times 1000 \times (660 - 100)$ $= 6048000 + 7560000$ $= 13608000 \text{ kcal/hr}$
	Pump flow rate (cooling tower range 5°C)	$= 13608000 / 5$ $= 2721600 / 1000$ $= 2721.6 \text{ m}^3/\text{hr}$	
	Power drawn by the motor	$= ((2721.6 / 3600) \times 15 \times 9.81) / (0.75 \times 0.93)$ $= 159.5 \text{ kW}$	

Answer any ONE of the following among four questions given below:

**N4
A**

The utility data for the upcoming commercial building is as follows

- Total Power required for the whole building including centrifugal chiller load : 1000 kW
- Building cooling load : 15,12,000 kCal/hr
- Centrifugal chiller power consumption : 0.45 kW/TR
- Cost of grid power including demand charges : Rs.10.35 /kWh

The management is considering the following two options for operating the building loads

Option 1: Operating all the loads through grid power

Option 2: Installing an 850 kW natural gas engine generator operating at full load with a WHRB and steam operated absorption chiller to meet part of the cooling load. Details of gas engine cogeneration system are given below:

- Total power generated from gas engine co-gen plant : 850 kW
- Gas engine efficiency : 38 %
- Heat absorbed for steam generation in WHRB (as a % of heat input to gas engine) : 22 %
- Specific steam consumption for VAM : 4.2 kg/TR
- Calorific value of Natural Gas : 8500 kcal/sm³
- Cost of Natural Gas : Rs.45/sm³
- Total enthalpy of steam : 660 kCal/kg
- Feed water temperature to WHRB : 60 °C

Calculate the following:

- i) Cost of generating one unit of electricity from the gas engine? (3 marks)
- ii) TR generated from Vapour Absorption Chiller driven by WHRB generated steam? (6 Marks)
- iii) Total energy cost per hour for option 1 & option 2. (10 Marks)
- iv) Which option is economically viable? (1 mark)

**N4
A-S**

i) Cost of generating one unit of electricity from gas engine?

$$\begin{aligned} \text{Fuel Consumption} &= 850 \text{ kW} \times 860 / (0.38 \times 8500) \\ &= \mathbf{226.31 \text{ sm}^3/\text{hr}} \\ \text{Cost per unit of electricity from gas engine} &= (226.31 \text{ sm}^3/\text{hr} \times 45 \text{ Rs./ sm}^3) / 850 \text{ kW} \\ &= \mathbf{Rs.11.98/ kWh} \end{aligned}$$

ii) TR generated from VAM driven by WHRB generated steam

$$\begin{aligned} \text{TR required by the building} &= 1512000/3024 \\ &= 500 \text{ TR} \\ \text{Heat absorbed by WHRB for Steam generation} &= 22\% \times (226.31 \times 8500) \\ &= \mathbf{4,23,199.7 \text{ kcal /hr}} \\ \text{Amount of steam generated} &= 423199.7/(660-60) \\ &= 705.33 \text{ kg/hr} \\ \text{TR generated by VAM} &= 705.33/4.2 = \mathbf{167.94 \text{ TR}} \end{aligned}$$

iii) Total energy cost per hour for option 1 & option 2.
Cost of electricity from Grid (Option 1) = 1000x 10.35 = **10,350 Rs./hr**

Total energy cost (Option 2)

Additional TR required = (500-167.94) = 332.06 TR

Power required from the grid for the additional TR = 332.06 x 0.45 = 149.43 kW

Cost of additional TR required = 149.43x 10.35 = 1546.60 Rs/hr

Cost of NG for Electricity = 226.31 sm³/hr X 45 Rs./ sm³
= **10,184 Rs./hr**
= 10184+1546.60
= **11,730.6 Rs./hr**

iv) Which option is economically viable?
Option - 1 is economically viable.

Or

N4 B During an energy audit of 5 stage Pre-heater (PH) kiln cement plant, following data were collected:

S. No.	Description	UoM	Value
1.	Clinker output	Tph	55
2.	Return dust in PH gas (% of Kiln feed)	%	9.4
3.	Reference Temperature	Deg C	0
4.	Reference pressure and the barometric pressure	mmWC	10336
5.	NCV of coal	kcal/kg	5500
6.	Cost of coal	Rs./ MT	9500
7.	Power cost	Rs./kWh	5.5
8.	Kiln annual running hours	Hrs/annum	7200

S.No	Flow measurements	PH exit/fan inlet	Cooler exhaust air	
1.	Average dynamic pressure	mmWC	16	17.13
2.	Static pressure	mmWC	-440	-28
3.	Temperature	Deg C	355	365
4.	Density of gas at Ref. temperature and pressure	kg/Nm ³	1.4	1.293
5.	Pitot tube constant		0.85	
6.	Fan input power	kW	333	62
7.	Fan efficiency	%	80	78
8.	Fan motor efficiency	%	95	95
9.	Diameter of measuring point	M	2	1.6
10.	Specific heat of PH gas	kcal/kg °C	0.248	0.245

Calculate the following:

- i. Heat loss in PH exit gas (kcal/kg clinker) [5 marks]
- ii. Heat loss in cooler vent air (kcal/kg clinker) [5 marks]
- iii. The recommendations made by energy auditor are as follows:
 - a) The 5 stage pre-heater may be upgraded to 6 stage, which will result in reduction in PH exit temperature by 50 °C and increase in pressure drop by 150 mm WC. Calculate the net annual monetary energy savings for proposed modification considering other parameters same as pre-modification. [8 marks]
 - b) To increase the cooler recuperation efficiency by reducing cooler exhaust temperature by 75 °C. Calculate the reduction in heat loss in cooler vent air (kcal/kg clinker) [2 marks]

N4 B-S Density of Pre-heater gas at PH Fan Inlet at prevailing temp., pressure conditions:

$$\rho_{T,P} = \rho_{STP} \times \frac{273 \times (10336 + P_s)}{(273 + T) \times 10336}$$

$$\rho_{T,P} = 1.40 \times \frac{273 \times (10336 - 440)}{(273 + 355) \times 10336} = 0.583 \text{ kg/m}^3$$

Velocity of PH gas

$$v = P_t \sqrt{\frac{2gP_d}{\rho_{T,P}}}$$

$$v = 0.85 \sqrt{\frac{2 \times 9.8 \times 16}{0.583}} = 19.7 \text{ m/sec}$$

$$\begin{aligned} \text{Volumetric flow rate of PH gas} &= \text{velocity} \times \text{duct cross-sectional area} \\ &= 19.7 \times (3.14 \times (1)^2) \\ &= 61.858 \text{ m}^3/\text{sec} \\ &= 61.858 \times 3600 \\ &= 222688 \text{ m}^3/\text{hr} \end{aligned}$$

$$\begin{aligned} \text{Specific volume of PH gas} &= 222688.8 \times 0.583/1.4 \\ &= 92733.97 \text{ Nm}^3/\text{hr} \\ &= 92733.97/55000 = \mathbf{1.686 \text{ Nm}^3/\text{kg clinker}} \end{aligned}$$

i. Heat loss in PH exit gas

$$Q1 = m_{ph} c_p \Delta T \quad (C_p \text{ of PH gas} = 0.248 \text{ kcal/kg } ^\circ\text{C})$$

$$\begin{aligned} Q1 &= 1.686 \times 1.4 \times 0.248 (355-0) \\ &= \mathbf{207.81 \text{ kcal/kg clinker}} \end{aligned}$$

[5 marks]

Similarly density of cooler vent air at cooler vent air fan Inlet at prevailing temp., pressure conditions:

$$\rho_{T,P} = \rho_{STP} \times \frac{273 \times (10336 + P_s)}{(273 + T) \times 10336}$$

$$\rho_{T,P} = 1.293 \times \frac{273 \times (10336 - 28)}{(273 + 365) \times 10336} = 0.5518 \text{ kg/m}^3$$

Velocity of cooler vent air in the fan inlet duct

$$v = P_t \sqrt{\frac{2gP_d}{\rho_{T,P}}}$$

$$v = 0.85 \sqrt{\frac{2 \times 9.8 \times 17.13}{0.5518}} = 20.96 \text{ m/sec}$$

$$\begin{aligned} \text{Volumetric cooler vent air} &= \text{velocity} \times \text{duct cross-sectional area} \\ &= \text{velocity} \times (\pi \times d^2)/4 \\ &= 20.96 \times (3.14 \times (1.6)^2) / 4 \\ &= 42.12 \text{ m}^3/\text{sec} \\ &= 42.12 \times 3600 \\ &= 151636 \text{ m}^3/\text{hr} \end{aligned}$$

$$\begin{aligned} \text{Specific volume of cooler vent air} &= 151636 \times 0.5518/1.293 \\ &= 64712 \text{ Nm}^3/\text{hr} \\ &= 64712/55000 = \mathbf{1.176 \text{ Nm}^3/\text{kg clinker}} \end{aligned}$$

ii. Heat loss in cooler vent air

$$Q2 = m_{ca} c_p \Delta T$$

$$\begin{aligned} Q2 &= 1.176 \times 1.293 \times 0.245 \times (365-0) \\ &= \mathbf{136 \text{ kcal/kg clinker}} \end{aligned}$$

[5 marks]

iii.

a) After up-gradation from 5 stage to 6 stage Pre-heater

Reduction in PH exit gas heat loss

$$Q = m_{ph} c_p \Delta T \quad (C_p \text{ of PH gas} = 0.248 \text{ kcal/kg } ^\circ\text{C})$$

$$\begin{aligned} Q1 &= 1.686 \times 1.4 \times 0.248 \times 50 \\ &= \mathbf{29.16 \text{ kcal/kg clinker}} \end{aligned}$$

$$\text{Equivalent coal savings (kg/hr)} = \text{Reduction heat loss (kcal/kg clinker)} \times \frac{\text{clinker output (kg/hr)}}{\text{NCV coal (kcal/kg coal)}}$$

$$\begin{aligned} \text{Equivalent coal saving} &= 29.16 \times \frac{55000}{5500} \text{ kg coal/hr} \\ &= 291.6 \text{ kg coal/hr} \end{aligned}$$

$$\text{Annual coal savings} = 291.6 \times \frac{7200}{1000} = 2099.52 \text{ MT}$$

$$\text{Annual monetary savings (Thermal)} = 2099.52 \times 9500 = \text{Rs. } 1,99,45,440 \text{ per annum}$$

Increase in PH fan power due to increase in pressure drop by 150 mm WC

$$\begin{aligned} \text{Fan power} &= \frac{\text{PH gas flow (m}^3/\text{hr)} \times \text{Rise in pressure drop (mm WC)}}{102 \times \text{fan efficiency (\%)} / 100 \times \text{motor efficiency (\%)} / 100} \text{ kW} \\ &= \frac{61.585 \times 150}{102 \times 80 / 100 \times 95 / 100} = 119.16 \text{ kW} \end{aligned}$$

$$\text{Increase in Annual Electrical energy cost} = 119.16 \times 7200 \times 5.5$$

$$= \text{Rs. } 47,18,974 \text{ per annum}$$

$$\text{Net annual monetary savings} = 1,99,45,440 - 47,18,974 = \text{Rs. } 1,52,26,466 \text{ per annum}$$

b) **Improving cooler efficiency**

Reduction in cooler vent air heat loss

$$Q = m_{\text{cooler vent}} c_p T \quad (C_p \text{ of cooler vent air} = 0.245 \text{ kcal/kg } ^\circ\text{C})$$

$$Q_1 = 1.176 \times 1.293 \times 0.245 \times 75 = 27.94 \text{ kcal/kg clinker}$$

Or

N4 C Sponge iron is processed in a steel melting shop for production of ingots. The daily sponge iron production in the steel plant is 300 tons. The plant has a coal fired captive power station to meet the entire power demand of the steel plant. The base year (2020) and current year (2021) energy consumption data are given below:

Parameter	UoM	Base year (2020)	Current Year (2021)
Sponge Iron production	T/day	300	300
Specific coal consumption	T/T	1.3	1.15
Specific power consumption	kWh/T	110	95
Yield	%	85	88
SEC of Steel Melting Shop	kWh/ton	850	830
Captive power station heat rate	kcal/kWh	3300	3100
GCV of Coal	kCal/kg	5000	5200

Calculate the following:

- Specific energy consumption of the plant in Million Kcals/ tonne of finished product for base year as well as for the current year. **15 Marks**
- Reduction in coal consumption per day in current compared to base year for the plant **5 Marks**

N4 C-S i) **Specific energy consumption of the plant For Base Year**

Specific energy consumption for sponge iron	= 1300 kg x 5000 + 110 kWh x 3300 = 6.863 million kcal/ Ton of SI
Total energy consumption for sponge iron /day	= 300X 6.863 = 2059 million kcal

Actual production considering 85% yield from sponge iron to ingot conversion	$= 300 \text{ Tons} \times 0.85 = 255 \text{ Tons/ day}$
Specific energy consumption for ingot	$= 850 \text{ kWh} \times 3300$ $= 2.81 \text{ million kcal/ ton of ingot}$
Total energy consumption for ingot production per day	$= 2.81 \times 255 = 716.55 \text{ million kcal}$
Plant specific energy consumption for production of finished product (ingot) during base year	$= (2059+716.55) / 255$ $= 10.89 \text{ million kcal/ ton}$

Specific energy consumption of the plant For Current Year

Specific energy consumption for sponge iron	$= 1150 \text{ kg} \times 5200 + 95 \text{ kWh} \times 3100$ $= 6.28 \text{ million kcal Ton of SI}$
Total energy consumption for sponge iron /day	$= 300 \times 6.28 = 1884 \text{ million kcal}$
Actual production considering 88% yield from sponge iron to ingot conversion	$= 300 \text{ T} \times 0.88 = 264 \text{ Tons / day}$
Specific energy consumption for ingot	$= 830 \text{ Kwh} \times 3100$ $= 2.573 \text{ million kcal/ ton of ingot}$
Total energy consumption for ingot production per day	$2.573 \times 264 = 679.27 \text{ million kcal}$
Plant specific energy consumption for production of finished product (ingot) during current year	$= (1884+679.27)/264$ $= 9.70 \text{ million kcal/ ton}$


ii) Reduction in coal consumption

Energy saving in sponge iron plant $= (6.863-6.28) \times 300 = 175 \text{ million kcals/day}$
Energy saving in steel melting plant $= (2.81 \times 255 - 2.57 \times 264) = 38 \text{ million kcal/day}$
Total energy saving $= 175 + 38 = 213 \text{ million kcal/day}$
Equivalent coal reduction (saving) $= 213 \times 10^6 / 5200 = 40.96 \text{ Tons per day}$

Or

**N4
D**

A thermal power plant is equipped with boiler and reheat steam turbine with the following details



PARAMETER	UNITS	HP TURBINE (INLET)	HP TURBINE (OUTLET/ CRH)	IP TURBINE (INLET/ HRH)	LP TURBINE INLET	CONDENSER
Pressure	Kg/cm ²	145	36.7	33	7	0.125
Temperature	°C	516	340	516	322	49
Enthalpy	Kcal/kg	813	735	834	741	610
Flow	TPH	684	635	635	545	545

LP turbine exhaust dryness fraction : 0.98
 Isentropic efficiency of HP turbine : 79.6%
 Isentropic enthalpy at LP turbine exhaust pressure : 559 kcal/kg
 Boiler feed water temperature : 241 °C
 Gear box efficiency : 98%
 Generator efficiency : 97%

Calculate:

- Isentropic enthalpy of HP turbine outlet steam. (4 Marks)
- Isentropic efficiency of LP turbine (5 Marks)
- Power generated from HP, IP and LP turbine in MW (6 Marks)
- Turbine heat rate and station Gross heat rate (kcal/kWh) (3 Marks)
- If the auxiliary power consumption is 8%, calculate the Net heat rate of the power plant in kcal/kWh. (2 Marks)

**N4
D-S**

i)	Isentropic efficiency of HP turbine	= 79.6 %
	Isentropic enthalpy of HP turbine outlet steam	$(813-x) = (813-735)/ 0.796$ $= 98$ $X = 813 -98$ $= 715 \text{ kcal/ kg}$
ii)	Enthalpy of exhaust of LP turbine	$= 49+0.98 \times (610-49)$ $= 599 \text{ kcal/kg}$
	Isentropic Efficiency of LP turbine	$= (741-599)/ (741-559)$ $= 78 \%$
iii)	Power generated from HP, MW	$= \text{Mass flow rate} \times \text{Enthalpy drop across HP turbine}/860$ $= (684 \times 1000 \times (813-735))/(860 \times 1000)$

		= 62.03 MW
	Power generated from IP, MW	= Mass flow rate x Enthalpy drop across IP turbine/860 = (635x1000x(834-741))/(860x1000) = 68.6 MW
	Power generated from LP, MW	= (545x1000x(741-599))/(860x1000) = 89.98 MW
iv)	Gross heat rate (kcal/kWh)	
	Total Power generated by Turbine in MW	= 62.03+68.6+89.98 = 220.67 MW
	Power generated by generator	= 220.67 MW x 0.98 x 0.97 = 209.76 MW
	Turbine heat rate	= (684 x (813-241) + 635*(834-735))/209.76 = 454113/209.76 = 2164.9 kcal/kWh
	Station Gross heat rate	SGHR cannot be calculated since boiler efficiency not given Or Any candidate calculates SGHR, assuming boiler efficiency between 85-88% marks are awarded (Refer guide book-4, page no 175,181 & 193)
v)	Station Net heat rate	Station net heat rate cannot be calculated since station gross heat rate could not be calculated Or Any candidate calculates SNHR by calculating SGHR on assuming boiler efficiency between 85-88% marks are awarded

..... **End of Section - III**