



## *"Best Practices in Energy Efficiency at Kankroli Tyre Plant "*



**Venue :**  
Energy Management Centre - Kerala  
Srikrishna Nagar, Sreekaryam  
Thiruvananthapuram 695017

**07<sup>th</sup> August 2024**

**Name:** Gaurav Bohra  
**Designation :** Dy. General Manager (EE&I)  
**Email :** [gbohra@jkmail.com](mailto:gbohra@jkmail.com)  
**Mobile No. :** +91 9799999940





# About the Organisation



- 1<sup>st</sup> Plant at Kankroli – 1976
- Initial capacity – 55 MT/ Day,
- Present Capacity 230 MT/Day
- 9 Plants in India - Capacity 1569 MT/Day
- 3 Plants in Mexico - Capacity 290 MT/Day

UEnM.01-PY.01

**ENERGY POLICY**

We at JK Tyre are committed to design, manufacture and distribute our products & services in an energy efficient manner to meet our mission statement of becoming a green company. We will continually improve our energy performance for sustainable growth by:

- Complying with all applicable legal and other requirements related to our energy use, consumption and efficiency.
- Taking measure in Energy Management System by being proactive, innovative and cost effective including procurement of energy efficient product & services.
- Enhancing effectiveness of energy management system by ensuring the availability of information and necessary resources to achieve the objectives and targets.
- Integrating energy policy into our business planning, decision making and performance review at appropriate level.

We commit to communicate this policy to all our employees, persons working for and on our behalf and also will make it available to all interested parties on request.

Authorised and Approved by  
 Arun K. Bajoria  
 Director & President  
 (International Operations)

Date : 01.01.2021  
Rev : 01

**JKTYRE**  
& INDUSTRIES LTD.



- IATF- 16949 : 2016
- ISO- 14001:2015
- ISO- 45001:2018
- ISO- 50001 :2018
- SA- 8000:2014
- ISO- 27001:2015
- .....Many More


## Certifications:-

- ISCC Plus FY 2024-25.
- Single Use Plastic Free FY 2024-25
- Management System From DNV FY2024-25.



# Energy Mapping (2023-24)

Total Energy Consumption-1944 K Cal/Kg of Product




| Annual GHG Emission Data 2023-24    |  | UoM             | Annual        |
|-------------------------------------|--|-----------------|---------------|
| Direct Emission                     |  | tCO2e           | 22024         |
| Indirect Emission - Imported Energy |  | tCO2e           | 25083         |
| Indirect Emission - Transportation  |  | tCO2e           | 5964          |
| <b>Total Emission</b>               |  | <b>tCO2e</b>    | <b>53072</b>  |
| Production                          |  | MT              | 53413         |
| <b>Emission Intensity</b>           |  | <b>tCO2e/MT</b> | <b>0.9936</b> |

**Uses of 20.2 % Renewable Energy**




# Present Energy Mix

## Plant Energy consumption (TJ ) FY 2023-24




## Plant Energy Mix (%) FY 2023-24






# Present Energy Mix

### Electricity Sources FY 2023-24




### Thermal Sources FY 2023-24





# Energy Journey





# Focus Areas

1. Reduction in Specific Energy Consumption
2. Reduction in Specific Water Consumption
3. Reduction in Specific Steam Consumption
4. Reduction in Specific Coal Consumption
5. Reduction in Specific Naphtha Consumption
6. Reduction in Specific Nitrogen Consumption
7. Increase in Boiler Efficiency
8. Compliance to Energy Conservation Act
9. Compliance to Indian Electricity Rules
- 10.Reduction in Steam Cost
- 11.Reduction in Power Cost
- 12.Reduction in Fuel Cost
- 13.Increase in Renewable Energy Use (%)
- 14.Reduction in GHG Intensity ( tCo2 equivalent) -Direct and Indirect Emissions
- 15.Procurement of Energy Efficient Appliances/ Machines

- Waste to Energy**
- Zero Land Fill**
- Condition Based Energy Monitoring**



# Annual Budget Allocation & Energy Consumption Pattern



## Total 85 Energy Projects

| Energy Phase | No. of Projects | Investment Rs. Lacs | Savings Rs Lacs | Payback Months |
|--------------|-----------------|---------------------|-----------------|----------------|
| Phase I      | 9               | 268                 | 420.8           | 8              |
| Phase II     | 10              | 113.4               | 144.3           | 10             |
| Phase III    | 9               | 157.5               | 118.4           | 18             |
| Phase IV     | 11              | 154                 | 153.5           | 12             |
| Phase V      | 13              | 142                 | 99.7            | 17             |
| Phase VI     | 7               | 86                  | 45              | 23             |
| Phase VII    | 11              | 174.5               | 99.7            | 21             |
| Phase VIII   | 3               | 292                 | 145             | 24             |
| Phase IX     | 3               | 46.5                | 28.2            | 20             |
| Phase-X      | 4               | 26.5                | 15.3            | 21             |
| Phase-XI     | 11              | 88.1                | 51.8            | 21             |
| Phase-XII    | 4               | 62                  | 41.1            | 18             |
| <b>Total</b> | <b>85</b>       | <b>1521.02</b>      | <b>1209.9</b>   | <b>15</b>      |

|  |  |
|--|--|
| <b>07</b> Energy Phase-VI<br>July-2017 | <b>11</b> Energy Phase-VII<br>July-2018  |
| <b>13</b> Energy Phase-V<br>July-2016  | <b>03</b> Energy Phase-VIII<br>July-2019 |
| <b>11</b> Energy Phase-IV<br>Oct-2015  | <b>03</b> Energy Phase-IX<br>Oct-2020    |
| <b>09</b> Energy Phase-III<br>Oct-2014 | <b>04</b> Energy Phase-X<br>Oct-2021     |
| <b>10</b> Energy Phase-II<br>Sept-2013 | <b>11</b> Energy Phase-XI<br>Sept-2022   |
| <b>09</b> Energy Phase-I<br>July-2012  | <b>4</b> Energy Phase-XII<br>July-2023   |





# Energy Saving Projects Implemented (2019-20)



| S No | Title of Project   | Annual Electrical Saving (M kWh) | Annual Electrical Saving (Rs million) | Annual Thermal Saving (M Kcal ) | Total Annual Savings (Rs million) | Total Annual Savings (Rs million) | Investment Made (Rs million) | Payback (Months) |
|------|--|----------------------------------|---------------------------------------|---------------------------------|-----------------------------------|-----------------------------------|------------------------------|------------------|
| 1    | Power Saving by conversion of a DC Motors with AC Motor and VFD on 3 Roll Calendar Line (Wind Up & Cooling Drum Motor) | 0.025                            | 0.20                                  |                                 |                                   | 0.20                              | 0.35                         | 21               |
| 2    | Power Saving by conversion of a DC Motors with AC Motor and VFD on 3 Roll Calendar Main Motor                          | 0.048                            | 0.39                                  |                                 |                                   | 0.39                              | 0.75                         | 23               |
| 3    | Reduction of Energy Consumption in Dip Unit Dryer Zone   | 0.000                            |                                       | 1820                            | 2.0                               | 2.00                              | 3.2                          | 19               |
| 4    | Power Saving by installation of Jet Nozzles (60 Points)  | 0.045                            | 0.36                                  |                                 |                                   | 0.36                              | 0.24                         | 8                |



# Energy Saving Projects Implemented (2020-21)



| S No | Title of Project   | Annual Electrical Saving (M kWh) | Annual Electrical Saving (Rs million) | Annual Thermal Saving (M Kcal ) | Total Annual Savings (Rs million) | Total Annual Savings (Rs million) | Investment Made (Rs million) | Payback (Months) |
|------|--|----------------------------------|---------------------------------------|---------------------------------|-----------------------------------|-----------------------------------|------------------------------|------------------|
| 1    | Reduction of Energy Consumption in Utility for Tyre Curing         | 1.9                              | 15.3                                  | 17912                           | 29.7                              | 13.6                              | 20                           | 18               |
| 2    | Power Saving by Upgradation of Energy Efficient AHU AHU's ( 2 Nos) | 0.2                              | 1.6                                   |                                 |                                   | 1.6                               | 5.2                          | 39               |
| 3    | Power Saving by installation of VFD on Mixer#5 TCU Pumps           | 0.0                              | 0.2                                   |                                 |                                   | 0.2                               | 0.5                          | 22               |
| 4    | Power Saving by installation of Jet Nozzles (250 Points)           | 0.1                              | 0.9                                   |                                 |                                   | 0.9                               | 1.3                          | 17               |



# Energy Saving Projects Implemented (2021-22)



| S<br>N<br>O | Title of Project  | Annual<br>Electrical<br>Saving<br>(M kWh) | Annual<br>Electrical<br>Saving<br>(Rs million) | Annual<br>Thermal<br>Saving<br>(M Kcal ) | Total<br>Annual<br>Savings<br>(Rs<br>million) | Total<br>Annual<br>Savings<br>(Rs<br>million) | Investment<br>Made<br>(Rs million) | Payback<br>(Months) |
|-------------|---|---|--|--|---|---|------------------------------------|---------------------|
| 1           | Power Saving by provision of VFD on Extruder & Calendar Roof ventilation Fan and Control Speed as per Seasonal Variation. | 0.04                                      | 0.3  |  |   | 0.3   | 0.5                                | 20                  |
| 2           | Power Saving by provision of VFD on Mixer Roof ventilation Fan and Control Speed as per Seasonal Variation.               | 0.02                                      | 0.2  |  |   | 0.2   | 0.3                                | 23                  |
| 3           | Power Saving by provision of VFD on Tyre Building Roof ventilation Fan and Control Speed as per Seasonal Variation.       | 0.02                                      | 0.2  |  |   | 0.2   | 0.35                               | 23                  |
| 4           | Power Saving by Upgradation of Energy Efficient AHU in place of old and inefficient AHU's ( Plant-III AHU # 4)            | 0.10                                      | 0.8  |  |   | 0.8   | 1.5                                | 22                  |
| 6           | Energy Saving by Direct Heating with LPG ipo In-direct Electrical Heating at Dryer Zone of 4 Roll Calendar                |   | 0.0  | 36.7                                     | 1.3   | 1.3   | 1.6                                | 15                  |
| 7           | Power Saving by provision of Existing VFD along with IE-3 Motor on DUAL Extruder 8.5' FD Mill and 10" FD Mill             | 0.17                                      | 1.4  |  |   | 1.42  | 2.60                               | 22                  |
| 8           | Power Saving by Upgradation of Energy Efficient AHU in place of old and inefficient AHU's ( Plant-I AHU # 6)              | 0.05                                      | 0.4  |  |   | 0.4   | 1.0                                | 27                  |



# Energy Saving Projects Implemented (2022-23)



| S<br>N<br>O | Title of Project   | Annual<br>Electrical<br>Saving<br>(M kWh) | Annual<br>Electrical<br>Saving<br>(Rs million) | Annual<br>Thermal<br>Saving<br>(M Kcal ) | Total<br>Annual<br>Savings<br>(Rs million) | Total<br>Annual<br>Savings<br>(Rs million) | Investment<br>Made<br>(Rs million) | Payback<br>(Months) |
|-------------|--|---|--|--|--|--|------------------------------------|---------------------|
| 1           | Power Saving by provision of VFD on DIP Unit Roof ventilation Fan and Control Speed as per Seasonal Variation.                                       | 0.02                                      | 0.16   |  |  | 0.16                                       | 0.30                               | 23                  |
| 2           | Power Saving by Provision of VFD in DIP Unit Exhaust Blower ( Dryer Zone, Normalising Zone & Heat Set Zone)  | 0.02                                      | 0.12   |  |  | 0.12                                       | 0.24                               | 24                  |
| 3           | Power Saving by Provision of PCI Air Recovery from Truck Sizes   | 0.01                                      | 0.10   |  |  | 0.10                                       | 0.20                               | 24                  |
| 4           | Power Saving in Compressed Area by New Air Meter Installation( Area Wise) and optimise the Air Consumption   | 0.04                                      | 0.34   |  |  | 0.34                                       | 0.50                               | 18                  |
| 5           | Power Saving by Energy Efficient Pump with VFD on Cooling Tower Supply & Return Pump   | 0.12                                      | 0.98   |  |  | 0.98                                       | 1.92                               | 23                  |
| 6           | Power Saving by provision of VFD along with Energy efficient IE-3 Motor on 3 Roll Calendar Feed Mill   | 0.13                                      | 1.05   |  |  | 1.05                                       | 1.80                               | 21                  |
| 7           | Steam saving by provision of insulation on Platen Outer Cavity on Tyre Curing presses ( Phase-I for 10 Nos of Platen Presses)                        |   |  | 177.0                                    | 0.33                                       | 0.33                                       | 0.35                               | 13                  |
| 8           | Steam saving by provision of insulation on HP Piston Valve ( Phase-I for 45 Nos of HP Valve)   |   |  | 95.6                                     | 0.22                                       | 0.22                                       | 0.25                               | 14                  |
| 9           | Steam saving by provision of insulation on Platen Outer Cavity on Tyre Curing presses ( Phase-II for 11 Nos of Platen Presses & 76 Nos of HP Valve ) |   |  | 345.1                                    | 0.8  | 0.8  | 0.80                               | 12                  |



# Energy Saving Projects Implemented (2023-24)



| S No | Title of Project   | Annual Electrical Saving (M kWh) | Annual Electrical Saving (Rs million) | Annual Thermal Saving (M Kcal ) | Total Annual Savings (Rs million) | Total Annual Savings (Rs million) | Investment Made (Rs million) | Payback (Months) |
|------|--|----------------------------------|---------------------------------------|---------------------------------|-----------------------------------|-----------------------------------|------------------------------|------------------|
| 1    | Power Saving by provision of VFD on Curing Section Ventilation Fan ( Roof Exhaust Fans ) & Control speed as per seasonal variation | 0.11                             | 0.89                                  |                                 |                                   | 0.89                              | 1.7                          | 23               |
| 2    | Reduction in Air Power Consumption by Air Pressure Optimisation in Mixing Section  | 0.03                             | 0.23                                  |                                 |                                   | 0.23                              | 0.4                          | 21               |
| 3    | Power Saving by Replacement of conventional Pump with Energy Efficient Pump for STP Section  | 0.06                             | 0.45                                  |                                 |                                   | 0.45                              | 0.90                         | 24               |
| 4    | Power Saving by Replacement of Old & Inefficient Pump with VFD on Cooling Tower Supply & Return Pump along with VFD in PCTR        | 0.11                             | 0.87                                  |                                 |                                   | 0.87                              | 1.7                          | 23               |
| 5    | Fuel Saving by increase in Condensate Recovery from Curing by provision of Jet Pump and use it in to Boiler Derator (Phase-I)      |                                  |                                       | 908                             | 2.6                               | 2.6                               | 3.2                          | 15               |
| 6    | Steam saving by provision of insulation on Platen Outer Cavity on Tyre Curing presses ( Phase-III for 22 Nos of Platen Presses)    |                                  |                                       | 345.3                           | 0.97                              | 0.97                              | 0.8                          | 10               |



## Summary of Energy Saving Projects Implemented in Last 5 Years




| Year       | No of Energy Saving Projects | Investment (INR Million) | Electrical Saving (Million kWh) | Thermal Savings (Million K Cal) | Savings (INR Million) | Impact on SEC GJ/Ton |
|------------|------------------------------|--------------------------|---------------------------------|---------------------------------|-----------------------|----------------------|
| FY 2019-20 | 4                            | 4.5                      | 0.12                            | 1820                            | 3.0                   | 0.15                 |
| FY 2020-21 | 7                            | 27.0                     | 2.3                             | 17912                           | 16.5                  | 1.45                 |
| FY 2021-22 | 8                            | 4.6                      | 0.41                            | 36.7                            | 7.9                   | 0.03                 |
| FY 2022-23 | 9                            | 6.4                      | 0.34                            | 617.6                           | 4.08                  | 0.07                 |
| FY 2023-24 | 6                            | 8.7                      | 2.43                            | 1254                            | 6.0                   | 0.09                 |

### Identification of Energy Projects based on:

- ✓ Technological Up gradation
- ✓ Plant Internal Findings
- ✓ Horizontal Deployment from other JK Tyre plants
- ✓ External Audit Finding



# Energy Consumption (Kcal/ Kg.) - Cured Tyre






# Benchmarking & Energy Saving Projects Implemented




## Internal Benchmarking

Energy Consumption-GJ/TON of Product

FY( 2023-24)



Specific Power Consumption- kWh/Kg FY( 2023-24)



### Kankroli Tyre Plant:

- ✓ Lowest Among Bias Tyre Manufacturing Plant for Specific Energy Consumption.
- ✓ Lowest Among All JK Tyre Plant for Specific Power Consumption.

Bias Tyre Manufacturing Plant

## Energy Saving Projects Implemented in Last Three Years

| Year       | No of Energy Saving Projects | Investment (INR Million) | Electrical Saving (Million kWh) | Thermal Savings (Million K Cal) | Savings (INR Million) | Impact on SEC GJ/Ton |
|------------|------------------------------|--------------------------|---------------------------------|---------------------------------|-----------------------|----------------------|
| FY 2019-20 | 4                            | 4.5                      | 0.12                            | 1820                            | 3.0                   | 0.15                 |
| FY 2020-21 | 7                            | 27.0                     | 2.3                             | 17912                           | 16.5                  | 1.45                 |
| FY 2021-22 | 8                            | 4.6                      | 0.41                            | 36.7                            | 7.9                   | 0.03                 |
| FY 2022-23 | 9                            | 6.4                      | 0.34                            | 617.6                           | 4.08                  | 0.07                 |
| FY 2023-24 | 6                            | 8.7                      | 2.43                            | 1254                            | 6.0                   | 0.09                 |







# Best Practice #1



**Project :** Reduce CO2 emission by using Horticulture waste as a fuel to 30 Ton Boiler

**Problem Definition :** Kankroli Tyre Plant is situated in 302 Acre of land and this land is completely covered with greeneries. On daily basis 0.75MT horticulture waste/tree leaves are generated and were being disposed as land fill.

Major challenge with this materials how to best utilise in the direction of Zero land fill and reduce CO2 in line with company mission of reduce carbon emission intensity to 50% by 2030

**Project Start Date** **Nov-21**

**Project Completion Date** **Jan-22**



# Countermeasure Identified

To Convert horticulture waste generated in KTP premises as Fuel Suitable for 30 Ton Boiler. For this Plant Team need to prepare solution for :

- Arrangement to make powder from dry leaves & twigs.
- Arrangement to feed powdered material/ Fuel in 30 ton Boiler.

## Development of Solution

**In- House Assembly  
of Components with  
available Resources**





# Development of Solution



Dry Leaves and twigs collected by Horticulture team


## Arrangement for Making & Feeding- Powdered Biomass - 30 MT Boiler



Bio Mass Powder Making Machine



Powdered Bio Mass



30 Ton Boiler

Venturi

Hopper

Conaflex Hose Pipe

Rotary Feeder

Venturi

Existing Boiler Secondary Air Fan



# • Measurement Of Benefits

- Total Availability of Horticulture Waste= 0.75 MT/Day

## Effectiveness & Sustenance of action:

- Horticulture waste is being measured in quantity before using and the same reduction trend is observed in Equivalent Coal Quantity.

| S No | FY      | Quantity (MT/Year) | Percentage of Total Fuel |
|------|---------|--------------------|--------------------------|
| 1    | 2021-22 | 29.8               | 0.1%                     |
| 2    | 2022-23 | 240.3              | 1.1 %                    |

## Tangible Benefits :-

- Saving of Rs. 3.0 Lacs / Year
- Payback : Immediate ( Used In-house Resource)



**19.5 Ton / Year**

## Intangible Benefits :-

## Standardization:-

- Saved Natural Resources.
- Training to Operatives





# Uniqueness of the Project & Continual Improvement



## Uniqueness of the Project

- Reduction in Zero land fill.
- Developed in-house alternate fuel for Boiler.
- Development of Solution with in-house Resources





# Best Practice # 2



## Project: Fuel saving by increase in condensate recovery from curing by provision of jet pump

### Problem Definition

On GH line There are Total 30 Curing Presses Condensate and Flash Steam Generated During Process is Collected in One Header and then Flow Through Self Pressure and Collected in One Common Collection Tank Where Condensate is Pumped to Deaerator. Condensate Flow From GH Trench Get Disturb Due to Back Pressure From Other Trench, There is Leakages in Header Line, Improper Line Sizing, Flash Steam Venting in Collection Tank, Also Observed That Bypass Valve of Presses Opened For Removing Condensate From Presses Because Old Traps is not Capable to Handle Large Flow of Condensate. Due to All These Causes Condensate Recovery is Less.

**Project Start Date :** April-2023

**Project Completion Date :** March-24

### Data Collection

#### Condensate recovery before

|                                   | Apr-23 | May-23 | Jun-23 | Jul-23 |
|-----------------------------------|--------|--------|--------|--------|
| Total steam sent (MT)             | 7066   | 7345   | 8056   | 8528   |
| Total conden sent recover (KL)    | 1749   | 1814   | 1848   | 2048   |
| Avg Plant condensate recovery (%) | 24.75  | 24.70  | 22.94  | 24.02  |
| Avg recovery of 4 months          | 24.10  |        |        |        |

#### Data Collection Tools:-

1. Condensate recovery meter

### Why Why Analysis

Condensate recovery not good



Condensate collection through self pressure



Wrong method selection of condensate recovery



# Best Practice # 2

## Counter Measure

- For collection of GH line condensate new flash jet pump to be install in which flash steam and condensate get separated in different lines and condensate force fully send to directly deaerator.

## Validation

- Flash steam and condensate is flowing through single line and partially flash steam venting in common condensate tank so flash steam and condensate line temporary separated by pilot project and all parameters were collected and found beneficiary.

## Solution Implemented

B  
E  
F  
O  
R  
E



Condensate recovery before

A  
F  
T  
E  
R



Condensate recovery after




# Best Practice # 2

## Results :-

- Condensate recovery increased by 4.99 %
- Total cost saving in 3 months = 155591 Rs.

| Condensate recovery After                               |                |        |         |              | Increase in Condensate recovery (%)             |                              | 4.99     | %             |    |
|---|----------------|--------|---------|--------------|---|------------------------------|----------|---------------|----|
|   | From 08 Aug-23 | Sep-23 | Oct-23  | <b>Total</b> | We get recovery if dont modify                  |                              | 5970     | KL            |    |
|   |                |        |         |              | recovered extra condensate after modification   | diffrence                    | 1227     | KL            |    |
| Total steam sent  | 6748           | 9529   | 8492    | 24769        | Enthalpy of comdensate                          |                              | 100      | Kcal/Kg       |    |
| Total condensate recover (KL)                           | 1943           | 2631   | 2622.29 | 7196.29      | Enthalpy of DM feed water                       |                              | 52       | Kcal/Kg       |    |
| Avg Plant condensate recovery %                         | 28.79          | 27.61  | 30.88   |              | Enthalpy diff                                   |                              | 48       | Kcal/Kg       |    |
| Avg recovery of 3 months                                | 29.09          |        |         |              | Total enthalpy saving from recovered condensate |                              | 58882710 | Kcal/Kg       |    |
| Average GCV of coal considered for saving               |                |        |         | <b>3406</b>  | Kcal/Kg   | Average prize of coal per MT |          | <b>9000</b>   | Rs |
| Total saving from recovered condensate in terms of coal |                |        |         | <b>17.29</b> | MT  | Total Cost saving            |          | <b>155591</b> | Rs |







# Best Practice # 3

**Project: Air power saving by optimising air pressure in mixing section.**

## Problem Definition

In our plant mixing section area one mixer having pneumatic ram which is required minimum 6.2 kg/cm<sup>2</sup> air pressure for operation, while in plant operation require 5.8 kg/cm<sup>2</sup> air pressure. Air power consumption is high in mixing area due to maintain air pressure up to 6.2 kg/cm<sup>2</sup> in all mixing section.

**Project Start Date :** June-2023


**Project Completion Date :** Dec-2023

## Data Collection

| Air power compressor 7 & 8 Before |        |        |        |        |
|-----------------------------------|--------|--------|--------|--------|
| Month                             | Jun-23 | Jul-23 | Aug-23 | Sep-23 |
| Air power consumption (kWh)       | 1720   | 1722   | 1742   | 1702   |

**Data Collection Tools:-**  
Energy Meters from IoT based System

### Why Why Analysis





# Best Practice # 3

## Counter Measure

- Air power reduction by using pressure reducing control valve for plant process air (air pressure 5.8 kg/cm<sup>2</sup>) and separate air line for mixer (air pressure 6.2 kg/cm<sup>2</sup>).

## Validation

A Pilot Project – Using Old air pressure reducing control valve Modification of System compatible for plant process air (air pressure 5.8 kg/cm<sup>2</sup>) with arrangement. Energy Consumption and Process Parameter Validated .

B  
E  
F  
O  
R  
E



Air Line in Mixing Section Before

A  
F  
T  
E  
R



Air Line in Mixing Section After Modification




# Best Practice # 3

## Results :-

- Air power consumption reduction in mixing section = 97 kWh/ Day
- Total cost saving in 3 months = 62041 Rs.

| Air power compressor 7 & 8 ((Avg kWh/Day) Before |        |        |        |        |
|--|--------|--------|--------|--------|
| Month  | Jun-23 | Jul-23 | Aug-23 | Sep-23 |
| Air power consumption (kWh)                      | 1720   | 1722   | 1742   | 1702   |

| Air power compressor 7 & 8 (Avg kWh/Day) After |        |        |        |
|--|--------|--------|--------|
| Month  | Oct-23 | Nov-23 | Dec-23 |
| Air power consumption (kWh)                    | 1624   | 1642   | 1606   |



**24 Ton / Year**



# Best Practice # 4



**Project:** Power saving by process optimization on cooling tower supply & return pump.

## Problem Definition

At Kankroli Tyre Plant on Cooling Tower Supply & Return Pump Power Consumption is High Because Multiple Pumps are Running to Achieve Specific Pressure Requirement With Manual Bypass Adjustment. Pumps are Running With Starter System so Speed Control Also Not Available.

**Project Start Date :** April-2023

**Project Completion Date :** March-24

## Data Collection


### Energy Used For Cooling Tower( FY 2022-23)

| S No | Particulars   | UOM      | Quantity |
|------|---|----------|----------|
| 1    | Power Consumption for Cooling Tower Supply & Return Pumping | Kwh/Day  | 4684     |
| 2    | Power Consumption for Cooling Tower Supply & Return Pumping | Kwh/Year | 1405200  |

### Data Collection Tools:-

1. Energy Meters from IoT based System

## Why Why Analysis





# Best Practice # 4



## Counter Measure

- To Use Single Energy Efficient on Cooling Tower Supply & Return Pump with IE3 Energy Efficient Motor and maintain pressure as per Process requirement
- Modify Existing System for Closed Loop Control through VFD for Power Optimization

## Validation

- A Pilot Project – Using Old available Single High Efficiency Pump process parameters achieved but still manual bypass need to be open frequently so Modification of System compatible for closed loop control with arrangement of available VFD. Energy Consumption and Process Parameter Validated .

## Solution Implemented

B  
E  
F  
O  
R  
E



Multiple Pumps on Cooling Tower Supply Pumps with Fixed Starter Panel

A  
F  
T  
E  
R



Single Energy Efficient Pump on Cooling Tower Supply Pumps with VFD




# Best Practice # 4

## Results :-

- 10.0 % Reduction in absolute Power Consumption= 518 kWh/Day
- Saving in Energy Consumption= 133.6 M Kcal/Year

| Monthly Average Power Consumption Trend of Cooling Tower ( kWh/ Day) |        |        |        |           |
|--|--------|--------|--------|-----------|
| YTD 22-23  | Apr-23 | May-23 | Jun-23 | YTD 23-24 |
| 4684   | 3968   | 4092   | 4438   | 4166      |



## Tangible Benefits :-

- Saving of Rs. 12.6 Lacs / Year
- Simple Payback of 1.6 Years

## Intangible Benefits :-

- Consistent Pressure & Process Water Temperature
- Ease of Maintenance.

## Standardization:-

- Changes in SOP
- Revised Process Parameter



**127 Ton / Year**



# Best Practice # 5

**Project:** Power saving by process optimization on STP section in pump house.

## Problem Definition

At Kankroli Tyre Plant on STP Section in Pump House Power Consumption is high Because High Power Pump is Used to Achieve Desired Pressure With Manual Bypass Adjustment. Pumps is Running With Starter System so Speed Control Also Not Available.

**Project Start Date :** June-2023

**Project Completion Date :** March-24


## Data Collection

### Energy Used For Cooling Tower( FY 2022-23)

| S No | Particulars   | UOM      | Quantity |
|------|---|----------|----------|
| 1    | Power Consumption for Cooling Tower Supply & Return Pumping | Kwh/Day  | 530      |
| 2    | Power Consumption for Cooling Tower Supply & Return Pumping | Kwh/Year | 158400   |

- Data Collection Tools:-**
1. Energy Meters from IoT based System

## Why Why Analysis



# Best Practice # 5

## Solution Implemented


### Counter Measure

- To Use Energy Efficient on STP pump with IE3 Energy Efficient Motor and maintain pressure as per Process requirement
- Modify Existing System for Closed Loop Control through VFD for Power Optimization

### Validation

- A Pilot Project – Using Old available Low Power Pump and process parameters achieved and Modification of System compatible for closed loop control with arrangement of available VFD. Energy Consumption and Process Parameter Validated .

B  
E  
F  
O  
R  
E



Old Inefficient Pumps on STP section with Fixed Starter Panel



A  
F  
T  
E  
R



Single Energy Efficient Pump on STP Section Pump with VFD







# Best Practice # 5

## Results :-

- Reduction in absolute Power Consumption= 153 kWh/Day
- Saving in Energy Consumption= 39.49 M Kcal/Year

| STP Power Consumption(Avg/Day) Before |        |        |        |        |        |
|---------------------------------------|--------|--------|--------|--------|--------|
| Month                                 | Jun-23 | Jul-23 | Aug-23 | Sep-23 | Oct-23 |
| STP power consumption (kWh)           | 500    | 528    | 542    | 538    | 544    |

| STP Power Consumption(Avg/Day) After |        |        |        |        |        |
|--------------------------------------|--------|--------|--------|--------|--------|
| Month                                | Nov-23 | Dec-23 | Jan-24 | Feb-24 | Mar-24 |
| STP power consumption (kWh)          | 380    | 377    | 385    | 379    | 365    |

## Tangible Benefits :-

- Saving of Rs. 3.70 Lacs / Year
- Simple Payback of 1.9 Years


## Intangible Benefits :-

- Consistent Pressure & Process Water Temperature
- Ease of Maintenance.

## Standardization:-

- Changes in SOP
- Revised Process Parameter

STP power consumption (Avg/Day kWh)



**37 Ton / Year**



# Best Practice # 6



**Project:** Optimising The Process to reduce Power consumption by provision of VFD with IE-3 Motor on DUAL Extruder 8.5" Feed Mill and 10" Feed Mill

## Problem Definition

At Kankroli Tyre Plant at Dual Extruder Feeding conveyor system from Mill to Extruder required feed width is fixed as motor is running with constant speed leading to high temperature of compound as there is no provision to reduce the width leading to lumpy generation that further produces defective product. In addition to this Power Consumption of 10" Extruder & 8.5" Extruder Feed Mill is High due to running of Inefficient Induction Motors with no provision of speed control.


## Data Collection

**Energy Used For 8.5 " FD Mill & 10" FD Mill ( FY 2019-20)**

| S No | Particulars                                     | UOM                  | Quantity |
|------|---|----------------------|----------|
| 1    | Power Consumption of 8.5 " Feed Mill            | Kwh/ Month           | 55743    |
| 2    | Power Consumption of 10 " Feed Mill             | Kwh/ Month           | 64462    |
| 3    | Power Consumption of Feed Conv- 8.5 " Feed Mill | Kwh/ Month           | 1373     |
| 4    | Power Consumption of Feed Conv- 10 " Feed Mill  | Kwh/ Month           | 1360     |
| 5    | Total Power Consumption                         | Kwh/ Month           | 122937   |
| 6    | Dual Production                                 | Eq Truck Tread/Month | 220191   |
| 7    | Specific Power Consumption for Feed Mill        | Kwh/Eq Truck Tread   | 0.558    |

**Data Collection Tools:-**

1. Energy Meters from IoT based System



## Counter Measure


- To Use Energy Efficient ( IE-3) Motor (160 KW) in place of Conventional Motor along with VFD to Control the Speed of the process.
- Modify Existing System and increase the Existing feed width of the Extruder by Reducing the Mill Speed keeping the feed volume Constant.

## Validation

- A Pilot Project – Trial Taken of Increase in Feed width by Rubber Technology team by arranging Local VFD Panel and establish the process . All Process & Energy Data Validated with respect to 20 % reduction in Motor Speed.


## Solution Implemented

B  
E  
F  
O  
R  
E



Conventional Motor with Fixed Starter Panel

A  
F  
T  
E  
R



Energy Efficient IE-3 Motor with VFD Panel



# Best Practice # 6

## Results Achieved

### Energy Benefits

- Saving in Power Consumption= 2.08 Lacs Kwh/Year
- 18.3 % Reduction in kWh/Eq. truck Tread of Product
- Elimination of Compound Lumpiness


### Tangible Benefits

- Saving of Rs. 17.1 Lacs / Year

### Intangible Benefits

- Lower Maintenance Cost.
- Better Process Control & Reduction in fatigue

Reduction in Specific Power Consumption ( kWh/ Eq Truck Tread)



### Standardization

- Change in SOP.
- Revised Process Parameter

### Uniqueness of the Project

- Optimization of feed temperature and product quality along with energy saving.
- Easy Maintenance of VFD Panel & Motor.
- Reduction in idling Losses by Reducing the Mill Speed.
- Simple Payback on Investment is 1.5 Years



**170 Ton / Year**



# Best Practice # 7



## **Project:**

### **Energy Saving by Process Optimization at Pre Cured Tread Rubber - Extruder**

At Kankroli Tyre Plant, Pre-Cured Tread Rubber Section, Extruder Tread booking temperature variation ( Specification :  $46 \pm 2$  Deg C) is there due to variation in Cooling Water Pressure. There is no pressure control from cooling tower and Fix pressure ( $4.0 \pm 0.2$  Kg/cm<sup>2</sup>) is running on all equipment's irrespective of machine requirement . In addition to this Old, Inefficient & Multiple Pumps were running with conventional motors on Cooling Tower Supply & Return Pump without any speed control.

Above process is based on old technology and need to upgrade for Improvement of Energy Efficiency & Process optimization.


**Project Start Date** : April-23

**Project Completion Date** : March-24



# Problem Definition

- ❑ Specific Power Consumption of PCTR Process : 0.218 kWh/Kg of Product
- ❑ Major Energy Loss at PCTR Extruder is Evident Through :
  - Conventional Motors & Pumps on Cooling Tower without any Speed control/ Open Loop Control.
  - Layout of Cooling Pipeline is not as per Machine Pressure Requirement.
  - High Scrap Generation due to inconsistent Booking Temperature



Extruder Booking Temperature-Process Capability Report ( Before)

Due to above Inefficiency in Existing Process there is High Energy Consumption.



# Countermeasure Identified along with Validation



## Countermeasure Identified

- To Use Single Energy Efficient on Cooling Tower Supply & Return Pump with IE3 Energy Efficient Motor and maintain pressure as per Process requirement.
- Modify Existing System for Closed Loop Control using Pressure Transmitter in line with VFD for Power Optimization.
- Pipe Line Modification based on Equipment Pressure Requirement.

## Validation

- A Pilot Project – Using Old available Pump and Modification of System compatible for closed loop control with arrangement of available VFD .  
Energy Consumption and Process Parameter Validated .



# Solution Implemented



## Solution Implemented -1



Energy Efficient Pump & Motor with VFD at-

- 1. Cooling Tower Supply Pump
- 2. Cooling Tower Return Pump

## Solution Implemented -2



Optimize PCTR Pressure by Relaying of Pipeline and Separate Circuit of 4.0 kg/cm<sup>2</sup> & 2.0 Kg/cm<sup>2</sup>

## Solution Implemented -3



Provision of Piston Valve to Stop Idle Consumption when Equipment Not in Use





# Results Achieved



## Results :-

- Reduction in Specific Power Consumption=15.1 %
- Saving in Power Consumption= 2.15 Lacs kWh/Year
- Elimination of Scrape due to Inconsistent Temperature

## Tangible Benefits :-



**262 Ton / Year**

- Saving of 17.4 Rs Lacs/year

## Intangible Benefits :-



- Lower Maintenance

## Standardization :-

- SOP provided to Operator's
- Training to Operator's
- Change Log Instruction


## Horizontal Deployment :-

Cooling Tower # 3







# Continual Improvement Over Last 3 Years




Specific Power Consumption ( kWh/Kg)




Specific Steam Consumption ( kg/Kg)




GHG Emission Intensity(tCo2e/MT)



Uses of Biomass as % of Total Fuel



Uses of Solar Power as % of Total Power



Uses of Renewable Energy as % of Total Energy



## A. Major Source of CO2 Emission at Kankroli Tyre Plant :

1. Fuel for Boiler
2. Power for Process Equipment
3. LPG for DIP Unit Process

### Carbon Neutrality Technique Used in Plant



Solar Plant Capacity – 3 MWp



Bio Mass – Briquettee

## B. Existing Boiler is Chain Grate Stocker Coal Fired Boiler & Present Use of Fuel :

- 75% Coal
- 25 % Bio Briquettes



Carbon Sequestration



Horticulture Waste



# Continual Improvement- Initiative on carbon Capture



## Estimated Carbon sink, Carbon sequestration and Carbon capture

| Parameter   | Unit                       | Value           |
|---|----------------------------|-----------------|
| a. Estimated total volume of wood in bole / trunk (Green)       | cum (m <sup>3</sup> )      | 9,976.74        |
| b. Estimated total weight of wood in bole / trunk (cum x 0.8 t) | tonnes (t)                 | 7,981.39        |
| c. Estimated total woody biomass (@1.71)*                       | tonnes (t)                 | 1,364.18        |
| d. Less moisture. Dry Biomass (c/2)                             | tonnes (t)                 | 6,824.09        |
| e. Estimated carbon in biomass (c/2)                            | tonnes (tc)                | 3,412.05        |
| f. Carbon capture (e x 44/12)                                   | tonnes (tCO <sub>2</sub> ) | <b>12,510.8</b> |

\* Biomass Expansion Factor (BEF) = Root 26% + Branches, Leaves, Bark, leaf litter 45% of the bole/trunk =71%

The carbon sequestration of 12,510.8 tCO<sub>2</sub> is estimated from 423,154 standing biomass from 69.974 ha (174.937 ac) of JKTIL Kankroli Tyre plant. 178.79 tonnes of CO<sub>2</sub> Per ha (71.51 tonnes of CO<sub>2</sub> per ac)CO<sub>2</sub> is offset by plantation.



Carbon Sequestration Study



# Way forward



## Way forward:

- 1. Installation of New Boiler compatible for 100 % uses of Biomass
- 2. Road Map for Reduction In Carbon Emission Intensity (e tCo2/ MT)- (Scope1+ Scope2)

| 2022-23 | 2023-24 | 2024-25 | 2025-26 | 2026-27 | 2027-28 | 2028-29 | 2029-30 |
|---------|---------|---------|---------|---------|---------|---------|---------|
| 0.907   | 0.858   | 0.812   | 0.769   | 0.728   | 0.689   | 0.652   | 0.617   |



# Key Actions Taken, Its sustainability & Maintenance




## Key Actions Taken

| Conversion of Conventional Motors to Energy Efficient Motors |                            |
|--|----------------------------|
| FY   | Energy Efficient Motors kW |
| 2017-18  | 112                        |
| 2018-19  | 344                        |
| 2019-20  | 1644                       |
| 2020-21  | 100                        |
| 2021-22  | 1850                       |
| 2022-23  | 305                        |


| Electrical Energy Audit |                       |
|-------------------------|-----------------------|
| FY                      | Vendor                |
| 2013-14                 | M/s Schneider         |
| 2017-18                 | M/s First Enterprises |
| 2021-22                 | M/s Siemens           |

| Reduction in Contact Demand |                 |
|-----------------------------|-----------------|
| FY                          | Contract Demand |
| 2020-21                     | 10500 MVA       |
| 2021-22                     | 9000 MVA        |
| 2022-23                     | 8500 MVA        |


## Key Electrical Parameters for Monitor & Control




132 KV Incomer KVA



132 KV Incomer Power



Incoming P.F.



Solar v/s DISCOM Generation



# Employee Training & Development on Energy Efficiency



## Employee Awareness & Training

**ENERGY AWARENESS**

- एक यूनिट बिजली की बचत का अर्थ 2 यूनिट बिजली का उत्पादन।
- 60 RPM (H.T) की मोटर 15 मिनट के व्यर्थ से चलने पर ₹750 का नुकसान तथा 30 RPM (H.T) की मोटर पर 350 ₹ का नुकसान होता है।
- मिल मोटर के 15 मिनट व्यर्थ चलने पर ₹110 का नुकसान।
- दीवार पंखे के 15 मिनट व्यर्थ पर चलने पर ₹ 7.5 का नुकसान
- पीसीआई एयर का ¼ इंच के छेद से प्रतिदिन व्यर्थ रिसाव होने पर ₹3600 का नुकसान होता है।
- 7 किलोग्राम/सेंटीमीटर स्टीम पाइप लाईन में 3 मिलीमीटर के छेद से व्यर्थ रिसाव होने पर 187 MT स्टीम का प्रतिवर्ष (₹3.74लाख) का नुकसान होता है।
- तेल की एक बूंद प्रति सेकंड अपव्यय होने का अर्थ 4000 लीटर प्रति वर्ष का नुकसान जिसकी कीमत ₹4.00 लाख होती है।
- पानी की एक बूंद प्रति सेकंड अपव्यय होने का अर्थ 1460 लीटर प्रति वर्ष का नुकसान।

IATF 16949 ISO 9001 ISO 14001 ISO 50001 ISO 45001 ISO27001 ISO/IEC 17025

**ENERGY AWARENESS**

**GHG EMISSION FOR ENERGY SOURCES**

- GHG Emission of 1 kWh / Day = 0.30 t CO2 / Year
- GHG Emission of 1 Kg of Coal / Day = 0.6 t CO2 / Year
- GHG Emission of 1 Kg of LPG / Day = 1.1 t CO2 / Year
- GHG Emission of 1 Ltrs of HSD / Day = 1.0 t CO2 / Year

**EMISSION FACTOR OF ENERGY SOURCES**

| S No | Energy Source | Emission Factor |
|------|---------------|-----------------|
| 1    | Electricity   | 0.82 kg CO2/kWh |
| 2    | Coal          | 94.6 (t CO2/TJ) |
| 3    | LPG           | 63.1 (t CO2/TJ) |
| 4    | HSD           | 74.1 (t CO2/TJ) |

IATF 16949 ISO 9001 ISO 14001 ISO 50001 ISO 45001 ISO27001 ISO/IEC 17025

ISO-50001 EMS

| Programme Title        | From       | To         |
|------------------------|------------|------------|
| Emms - 50001 Standards | 01/01/2021 | 31/03/2021 |

| VENUE      | Deming Hall            | Coordinator: PD Chaudhary |       |           |
|------------|------------------------|---------------------------|-------|-----------|
| FACILITIES | No. 5, W. Road, (East) |                           |       |           |
| S.N.       | SAP CODE               | Name                      | POSTO | SIGNATURE |
| 1          | 16646                  | Mayank Nagri              | SSU-1 |           |
| 2          | 2402                   | Abhishek Chhaya           | SSU-1 |           |
| 3          | 24352                  | Siddhant Sodani           | SSU-1 |           |
| 4          | 17118                  | Ravi Sharma               | SSU-1 |           |
| 5          | 25333                  | Prateek Sharma            | SSU-1 |           |
| 6          | 2535                   | Mohit Bhandari            | SSU-1 |           |
| 7          | 17329                  | Kailash Dhanraj           | SSU-1 |           |
| 8          | 1109                   | Vishwan Singh             | SSU-1 |           |

**TICIPANT LIST OF LAB. PERSON SSU4**

| NAME   | TRAINING IN HOURS | DATE       |            |
|--------|-------------------|------------|------------|
| DICHYA | 3 HOURS           | 24.08.2021 |            |
| HATIK  | 3 HOURS           | 24.08.2021 |            |
| MEEENA | 3 HOURS           | 24.08.2021 |            |
| A.MALI | 3 HOURS           | 24.08.2021 |            |
| BAGORA | 3 HOURS           | 24.08.2021 |            |
| VAT    | 3 HOURS           | 24.08.2021 |            |
| 1765   | SANDEEP PANCHAL   | 3 HOURS    | 24.08.2021 |
| 10958  | KC JOSHI          | 3 HOURS    | 24.08.2021 |

### Energy Awareness Displays Inside Plant

### Energy Management Training to MCS & Operatives


## Development on Energy Efficiency

### Conversion of Conventional Motors to Energy Efficient Motors

| FY      | Energy Efficient Motors kW |
|---------|----------------------------|
| 2020-21 | 100                        |
| 2021-22 | 1850                       |
| 2022-23 | 305                        |

### Electrical Energy Audit

| FY      | Vendor                |
|---------|-----------------------|
| 2013-14 | M/s Schneider         |
| 2017-18 | M/s First Enterprises |
| 2021-22 | M/s Siemens           |





# Energy Management ISO 50001



## JK Tyre & Industries Ltd. EnMS Apex Manual

|  |  |                                       |
|--|--|---------------------------------------|
|  | <b>ENERGY MANAGEMENT SYSTEM –<br/>APEX EnMS MANUAL</b> | Doc No. UEnM.00-AM.01<br>Page 1 of 66 |
|--|--|---------------------------------------|

PRODUCT RANGE: AUTOMOTIVE TYRES (BIAS & RADIAL), TUBES & FLAPS


  

AND  
**CAVENDISH**  
(A JK TYRE ASSOCIATE)

This EnMS Apex Manual is the property of JK Tyre & Industries Ltd., Patriot House, 3 Bahadur Shah Zafar Marg, New Delhi. This must not be reproduced by anybody in part or in full without the permission of Corporate Management Representative.

### Process



### Integrated Procedure

- PR-01 Document Data Control Feb.2020
- PR-02 Control of Record Feb.2020
- PR-03 Internal Audit Feb.20
- PR-04 Control of Non Confirming Product Feb.20
- PR-05 Corrective Action Feb.20
- PR-06 Preventive Action Feb.20
- PR-07 Training Feb.20
- PR-08 Mgmt. Review Feb.20

### EnMS Common Procedure

- 1 Legal-UEnM.01-PR-1 Feb.20
- 2 Energy Review Baseline EnPI\_UEnM 01-PR 02 Feb.20
- 3 Objectives, Targets & MAP\_UEnM.01-PR.03 Feb.20
- 4 Int Comm\_UEnM.01-PR.04 Feb.20
- 5 External communication\_UEnM.01-PR.05 Feb.20
- 6 Operation Control\_UEnM.01-PR.06 Feb.20
- 7 Design\_UEnM.01-PR.07 Feb.20
- 8 Procurement\_UEnM.01-PR.08 Feb.20
- 9 Monitoring\_UEnM.01-PR.09 Feb.20








# EnMS at KTP and Involvement of Stakeholders



## KTP EnMS 50001



## External Stakeholders -Best Practices: Vendor/Supplier/Contractor

- ✓ Energy Efficiency Parameter is part of Technical specification before procurement
- ✓ Classification of Material based on Energy Efficiency parameter.
- ✓ After received of material all the energy efficiency parameter verified by vendor and it is linked with payment terms and condition .
- ✓ Product LCA Study Done for High Volume Product (Tyre Size 10.00-20\_JET XTRA XLM\_16PR\_J\_TT) and Improvement Initiative Started by Design Team .



# Energy Policy & ISO 50001



UEnM.01-PY.01

## ENERGY POLICY

We at JK Tyre are committed to design, manufacture and distribute our products & services in an energy efficient manner to become a green company. We will continually improve our energy performance for sustainable growth by:

- Complying with all applicable legal and other requirements related to our energy use, consumption and efficiency.
- Taking measure in Energy Management System by being proactive, innovative and cost effective including procurement of energy efficient product & services.
- Enhancing effectiveness of energy management system by ensuring the availability of information and necessary resources to achieve the objectives and targets.
- Integrating energy policy into our business planning, decision making and performance review at appropriate level.

We commit to communicate this policy to all our employees, persons working for and on our behalf and also will make it available to all interested parties on request.

Date: 08.11.2021  
Rev: 02

Authorised and Approved by  
Arun K. Bajoria  
Director & President  
(International Operations)



UMSS.01-PY.01

## Mission Statement on Sustainable Growth


Being cognizant of the need of sustainable growth and dwindling stock of natural capital, we commit ourselves to the attainment of the following Ten - Natural Capital Commandments.

1. Reduce specific consumption of energy and water by 2-5% every year over next ten years.
2. Reduce specific generation of waste and reduce the quantum of waste going to land fills by 2-5% every year over next ten years.
3. Increase use of renewable, including renewable energy by 2-5% every year in place of non-renewable over next ten years.
4. Reduce specific green house gas emissions and other process emissions by 2-5% every year over next ten years and explore opportunities through Clean Development Mechanism (CDM) & other Carbon Exchange Programs.
5. Increase use of recyclables and enhance recyclables of resources embedded in the product by 2-5% every year over next ten years.
6. Increase the share of harvested rainwater in the overall annual use of water by 2-5% every year over next ten years.
7. Incorporate life cycle assessment criteria for evaluating new and alternative technologies & products.
8. Strive to adopt green purchase policy and incorporate latest clean technologies.
9. Take lead in promoting and managing product stewardship program, by forging partnerships with businesses and communities.
10. Reduce depletion of natural capital, which is directly attributable to company's activities, products and services by 2-5% every year over next ten years.

We also commit to demonstrate attainment of these commandments in our pursuit to certifications such as IATF 16949, ISO 9001, ISO 14001, ISO 45001, SA 8000, ISO 50001, ISO 27001, British Safety Council - Sword of Honor & Globe of Honor Award, ISO 22301, Green Buildings, Eco Labels Sustainability reporting, Water Positivity and 100% use of renewable energy.

Date : 01.01.2021  
Rev : 01

Authorised and Approved by  
Arun K. Bajoria  
Director & President  
(International Operations)



Reduce Carbon Emission Intensity to 50% by 2030



# Kankroli Tyre Plant is Asia's First & World's Second Tyre Plant to get ISO 50001 Certification





# Energy Efficiency as Branding of Organisation



**CII GreenCo Platinum Rating 2022-2025**

**BEE - National Energy Conservation Awards 2021**

**BSC-Globe of Honor-Five Star Rating**

**Rajasthan Energy Conservation Award-2022**



**CII- Energy Efficient Unit-2022**

**CII- Young & Emerging Leader-2022 -Mr Abhishek Gaggar "2nd Runner Up "**

**6th CII National Energy Efficiency Circle Competition'2022- Appreciation( Large Sector)**

**6th CII National Energy Efficiency Circle Competition'2022- 2nd Runner Up( Large Sector)**



# PAT : Designated Consumer (DC)



As per the Ministry of Power’s (MoP) notification dated 6th June 2023, tyre manufacturing plants with energy consumption of 7,000 MTOE per year or more are expected to qualify as a Designated Consumer (DC) under the Bureau of Energy Efficiency’s (BEE) flagship Perform Achieve and Trade (PAT) scheme.

| TOE Calculation Total FY-2023-24<br>(Conventional+Renewable) |         |          |       | TOE Calculation Total (Conventional)<br>FY-2023-24 |         |          |      |
|--|---------|----------|-------|--|---------|----------|------|
|  |         |          | TOE   |  |         |          | TOE  |
| <b>Total Power</b>   | kWh     | 38270219 | 3291  | <b>Total Power</b>                                 | kWh     | 34643456 | 2979 |
| <b>Coal</b>  | MT      | 24907    |       | <b>Coal</b>  | MT      | 17031    |      |
| <b>GCV</b>   | Kcal/Kg | 3453     | 8601  | <b>GCV</b>   | Kcal/Kg | 3453     | 5881 |
| <b>LPG</b>   | MT      | 746      |       | <b>LPG</b>   | MT      | 746      |      |
| <b>GCV</b>   | Kcal Kg | 3453     | 258   | <b>GCV</b>   | Kcal Kg | 3453     | 258  |
| <b>Total</b>   |         |          | 12150 | <b>Total</b>                                       |         |          | 9118 |

### Query:-

- Does the Scope of TOE for PAT only production & process or all other support services(Canteen/MHE etc.)?
- How the benchmarking data is been calculated for tyre industries ?
- In TOE calculation Renewable energy to be included or not ?
- Do we have to consider GHG Scope 1,2,3 for calculation of TOE ?



**Thank you !**

JK Tyre & Industries Ltd.  
Kankroli Tyre Plant  
PO – Tyre Factory  
Jay kay Gram , Kankroli  
Dist:- Rajasamand – Rajasthan  
Pin - 313342